



Monte Carlo Simulation-based Sensitivity Analysis of the model of a Thermal-Hydraulic Passive System

Enrico Zio, Nicola Pedroni

► To cite this version:

Enrico Zio, Nicola Pedroni. Monte Carlo Simulation-based Sensitivity Analysis of the model of a Thermal-Hydraulic Passive System. Reliability Engineering and System Safety, 2012, 107, pp.90-106. 10.1016/j.ress.2011.08.006 . hal-00658555

HAL Id: hal-00658555

<https://centralesupelec.hal.science/hal-00658555>

Submitted on 26 Jul 2012

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Monte Carlo Simulation-based Sensitivity Analysis of the Model of a Thermal-Hydraulic Passive System

E. Zio^{1, 2} and N. Pedroni²

¹Ecole Centrale Paris-Supelec, Paris, France
E-mail: enrico.zio@ecp.fr, enrico.zio@supelec.fr

²Energy Department, Politecnico di Milano, Milan, Italy
E-mail address: enrico.zio@polimi.it

Abstract

Thermal-Hydraulic (T-H) passive safety systems are potentially more reliable than active systems, and for this reason are expected to improve the safety of nuclear power plants.

However, uncertainties are present in the operation and modeling of a T-H passive system and the system may find itself unable to accomplish its function. For the analysis of the system functional failures, a mechanistic code is used and the probability of failure is estimated based on a Monte Carlo (MC) sample of code runs which propagate the uncertainties in the model and numerical values of its parameters/variables.

Within this framework, sensitivity analysis aims at determining the contribution of the individual uncertain parameters (i.e., the inputs to the mechanistic code) to i) the uncertainty in the outputs of the T-H model code and ii) the probability of functional failure of the passive system. The analysis requires multiple (e.g., many hundreds or thousands) evaluations of the code for different combinations of system inputs: this makes the associated computational effort prohibitive in those practical cases in which the computer code requires several hours to run a single simulation.

To tackle the computational issue, in this work the use of the Subset Simulation (SS) and Line Sampling (LS) methods is investigated. The methods are tested on two case studies: the first one is based on the well-known Ishigami function [1]; the second one involves the natural convection cooling in a Gas-cooled Fast Reactor (GFR) after a Loss of Coolant Accident (LOCA) [2].

Keywords: nuclear passive system, functional failure probability, reliability sensitivity analysis, Subset Simulation, Line Sampling, Sobol indices.

1 Introduction

Modern nuclear reactor concepts make use of passive safety features, which do not need external input (especially energy) to operate [3] and, thus, are expected to improve the safety of nuclear

power plants because of simplicity and reduction of both human interactions and hardware failures [4]-[6].

However, the *aleatory* and *epistemic* uncertainties involved in the *operation* and *modeling* of passive systems are usually larger than for active systems [7], [8]. Due to these uncertainties, the physical phenomena involved in the passive system functioning (e.g., natural circulation) might develop in such a way to lead the system to fail its function (e.g., decay heat removal): actually, deviations in the natural forces and in the conditions of the underlying physical principles from the expected ones can impair the function of the system itself [9]-[21]. In the analysis of such *functional failure* behavior [10], the passive system is modeled by a mechanistic Thermal-Hydraulic (T-H) code and the probability of failing to perform the required function is estimated based on a Monte Carlo (MC) sample of code runs which propagate the uncertainties in the model and numerical values of its parameters/variables [22]-[38].

Within this framework, the objective of sensitivity analysis is twofold: i) the determination of the contribution of the individual uncertain parameters/variables (i.e., the inputs to the T-H code) to the uncertainty in the outputs of the T-H model code; ii) the quantification of the importance of the individual uncertain parameters/variables in affecting the performance (i.e., in practice, the functional failure probability) of the passive system [39]-[41]. In this view, the sensitivity analysis outcomes provide two important insights. On the one side, the analyst can identify those parameters/variables that are not important and may be excluded from the modeling and analysis; on the opposite side, the analyst is able to identify those parameters/variables whose epistemic uncertainty plays a major role in determining the functional failure of the T-H passive system: consequently, his/her efforts can be focused on increasing the state-of-knowledge on these important parameters/variables and the related physical phenomena (for example, by the collection of experimental data one may achieve an improvement in the state-of-knowledge on the correlations used to model the heat transfer process in natural convection, and a corresponding reduction in the uncertainty) [30], [38]. In the present context of passive system functional failure probability assessment the attention will be mainly focused on this latter aspect, i.e., the identification of those uncertain variables playing a key role in the determination of the passive system performance.

In all generality, approaches to sensitivity analysis can be either *local* or *global*. As the name suggests, local methods consider the variation in the system model output that results from a local perturbation about some *nominal* input value. In the limit view, the sensitivity measure of the contribution of a generic uncertain input parameter to the uncertainty of the output is the *partial*

derivative of the output with respect to the input parameter itself calculated around the nominal values of the input parameters. Such measure identifies the critical parameters as those whose variation leads to the most variation in the output [39], [42]. On the contrary, global techniques aim at determining which of the uncertain input parameters influence the output the most when the uncertainty in the input parameters is *propagated* through the system model [43]. In this view, the term “global” has two meanings: the first one is that, for one input parameter whose uncertainty importance is evaluated, the effect of the *entire* uncertainty distribution of this parameter is considered; the second one is that the importance of this input parameter should be evaluated with *all* other input parameters varying as well [44]. Examples of methods for global sensitivity analysis include the so-called *variance-based* techniques (such as those relying on the computation of Sobol indices [1], [39], [44]-[46] or the Fourier Amplitude Sensitivity Test (FAST) [47]) and the more recent *moment independent* techniques [43], [48]-[52]. The interested reader may refer to [39], [42], [53]-[58] for detailed and updated surveys on sensitivity analysis methods.

Regardless of the technique employed, sensitivity analysis relies on *multiple* (e.g., many hundreds or thousands) evaluations of the system model (code) for different combinations of system inputs. This makes the associated computational effort very high and at times prohibitive in practical cases in which the computer codes require several hours (or even days) to run a single simulation [32], [59]¹. Further, in the present context of nuclear passive systems, the computational issue is even more dramatic because the estimation of the functional failure probability is *also* of interest *besides* the sensitivity analysis of the passive system performance: as a consequence, the (typically, hundreds of thousands) simulations performed for estimating the functional failure probability have to be *added* to those carried out for the sensitivity analysis.

In light of the computational problem, the main objective of the present study is to show the possibility of efficiently *embedding* the sensitivity analysis of the performance of a nuclear passive system *within* the estimation of its functional failure probability, while resorting to a reasonably *limited* number of system model code evaluations. To this aim, the use of two advanced Monte Carlo Simulation (MCS) methods, namely Subset Simulation (SS) [60], [61] and Line Sampling (LS) [62], [63] is investigated.

In the SS approach, the functional failure probability is expressed as a product of conditional probabilities of some chosen intermediate events. Then, the problem of evaluating the probability of functional failure is tackled by performing a sequence of simulations of these intermediate events in

¹ For example, the computer code RELAP5-3D, which is used to describe the thermal-hydraulic behavior of nuclear systems, may take up to twenty hours per run in some applications.

their conditional probability spaces; the necessary conditional samples are generated through successive Markov Chain Monte Carlo (MCMC) simulations [64], in a way to gradually populate the intermediate conditional regions until the final functional failure region is reached. Two approaches of literature are here considered for performing the sensitivity analysis of the passive system performance by SS: the first one is *local* and embraces the so-called concept of *reliability sensitivity*, in which the sensitivity of the performance of the passive system to a given uncertain input variable is quantified as the *partial derivative* of the system failure probability with respect to the parameters (e.g., the mean, the variance, ...) of the probability distribution of the input variable itself [65]; the second one is *global* and employs the conditional samples generated by MCMC simulation to obtain the *entire distribution* of the system failure probability conditional on the values of the individual uncertain input parameters/variables [66], [67].

In the LS method, lines, instead of random points, are used to probe the failure domain of the multi-dimensional problem under analysis. An “important vector” is optimally determined to point towards the failure domain of interest and a number of conditional, one-dimensional problems are solved along such direction, in place of the multi-dimensional problem [62], [63]. In this approach, the sensitivity of the passive system performance to the uncertain system input parameters/variables can be studied through the examination of the elements of the LS important vector pointing to the failure region: a *local* informative measure of the relevance of a given uncertain variable in affecting the performance (i.e., in practice, the functional failure probability) of the passive system is the magnitude of the corresponding element in the LS important vector [68]-[71].

The SS- and LS-based approaches to sensitivity analysis are tested on two case studies: the first one is based on the highly nonlinear and non-monotonous Ishigami function [1], [39]; the second one involves the natural convection cooling in a Gas-cooled Fast Reactor (GFR) after a Loss of Coolant Accident (LOCA) [2]. The results obtained by the SS- and LS-based sensitivity analysis techniques are compared to those produced by *global* first- and total-order Sobol indices [39], [45].

In synthesis, the main contributions of the present paper are the following:

- *applying* the SS and LS methods to *embed* the sensitivity analysis of the performance of a nuclear passive system *within* the estimation of its failure probability, while resorting to a reasonably *limited* number of system model code evaluations: to the best of the authors’ knowledge, this is the first time that SS- and LS-based sensitivity analysis methods are applied to nuclear passive systems;

- *comparing* the results obtained by the following approaches to sensitivity analysis: i) SS-based local and global (reliability) sensitivity analyses, ii) LS-based local (reliability) sensitivity analysis and iii) “classical” variance-based global sensitivity analysis relying on the computation of Sobol indices;
- *challenging* approaches i)-iii) mentioned above in problems where the failure region of the passive system is composed by *multiple, disconnected* parts.

The reminder of the paper is organized as follows. In Section 2, a snapshot on the functional failure analysis of T-H passive systems is given. In Section 3, the SS and LS methods here employed for efficiently embedding the sensitivity analysis of the performance of a nuclear passive system *within* the estimation of its functional failure probability are presented. In Sections 4 and 5, the case studies concerning the Ishigami function and the passive cooling of a GFR are presented, together with the corresponding results. Finally, conclusions are provided in the last Section.

2 Functional failure analysis of T-H passive systems

The basic steps of a functional failure analysis of a T-H passive system are [24]:

1. Detailed modeling of the system response by means of a deterministic, best-estimate (typically long-running) T-H code.
2. Identification of the vector $\mathbf{x} = \{x_1, x_2, \dots, x_j, \dots, x_{n_i}\}$ of parameters/variables, models and correlations (i.e., the inputs to the T-H code) which contribute to the *uncertainty* in the vector $\mathbf{y} = \{y_1, y_2, \dots, y_l, \dots, y_{n_o}\}$ of the outputs of the best-estimate T-H calculations.
3. Propagation of the uncertainties associated to the identified relevant parameters, models and correlations $\mathbf{x}$ (step 2. above) through the deterministic, long-running T-H code in order to estimate the functional failure probability $P(F)$ of the passive system. Formally, let $Y(\mathbf{x})$ be a scalar function indicating the performance of the T-H passive system (e.g., the fuel peak cladding temperature during an accidental transient) and α_Y a threshold value (imposed e.g. by the regulatory authorities) defining the criterion of loss of system functionality. For illustrating purposes, let us assume that the passive system fails if $Y(\mathbf{x}) > \alpha_Y$; equivalently, introducing a variable called Limit State Function (LSF) or Performance Function (PF) as $g_x(\mathbf{x}) = Y(\mathbf{x}) - \alpha_Y$, failure occurs if $g_x(\mathbf{x}) > 0$. The probability $P(F)$ of system functional failure can then be expressed by the multidimensional integral:

$$P(F) = \iiint \dots \int I_F(\mathbf{x}) q(\mathbf{x}) d\mathbf{x} \quad (1)$$

where $q(\cdot)$ is the joint Probability Density Function (PDF) representing the uncertainty in the parameters $\mathbf{x}$, F is the failure region (where $g_x(\cdot) > 0$) and $I_F(\cdot)$ is an indicator function such that $I_F(\mathbf{x}) = 1$, if $\mathbf{x} \in F$ and $I_F(\mathbf{x}) = 0$, otherwise. Notice that the evaluation of integral (1) above entails *multiple* (e.g., many thousands) evaluations of the T-H code for different sampled combinations of system inputs.

4. Perform a sensitivity study to determine the contribution of the individual uncertain parameters $\mathbf{x} = \{x_1, x_2, \dots, x_j, \dots, x_{n_i}\}$ (i.e., the inputs to the T-H code) to i) the uncertainty in the outputs $\mathbf{y} = \{y_1, y_2, \dots, y_l, \dots, y_{n_o}\}$ of the T-H model code and ii) the functional failure probability of the T-H passive system. As is true for uncertainty propagation (step 3. above), sensitivity analysis relies on *multiple* evaluations of the code for different combinations of system inputs.

The computational burden posed by the uncertainty propagation and sensitivity analysis of steps 3. and 4. above is addressed by resorting to the Subset Simulation (SS) [60], [61] and Line Sampling (LS) [62], [63] techniques, whose main concepts are given in the following Section.

3 Computational methods employed in this study

In this Section, the SS (Sections 3.1) and LS (Sections 3.2) methods employed in this study for *embedding* an efficient sensitivity analysis of the performance of a nuclear passive system *within* the estimation of its functional failure probability are presented.

3.1 Subset Simulation

The Subset Simulation (SS) algorithm and its use for sensitivity analysis are briefly illustrated in Sections 3.1.1 and 3.1.2, respectively.

3.1.1 The algorithm

The idea underlying the Subset Simulation (SS) method is to convert the simulation of an event (e.g., the rare failure event) into a sequence of simulations of intermediate conditional events corresponding to subsets (or subregions) of the uncertain input parameter space: in this way, a rare event simulation is converted into a sequence of simulations of more frequent events.

During simulation, the conditional samples (lying in the intermediate subsets or subregions) are generated by means of Markov chains; by so doing, the conditional samples gradually populate the successive intermediate subsets (or subregions) up to the target (failure) region [60], [61].

In extreme synthesis, the SS algorithm proceeds as follows [60], [61], [66], [67]. First, N vectors $\{\mathbf{x}_0^k: k = 1, 2, \dots, N\}$ are sampled by standard MCS, i.e., from the original probability density function $q(\cdot)$. The corresponding values of the response variable $\{Y(\mathbf{x}_0^k): k = 1, 2, \dots, N\}$ are then computed and the first threshold value y_1 (identifying the first intermediate conditional event) is chosen as the $(1 - p_0)N^{\text{th}}$ value in the increasing list of values $\{Y(\mathbf{x}_0^k): k = 1, 2, \dots, N\}$. With this choice of y_1 , there are now p_0N samples among $\{\mathbf{x}_0^k: k = 1, 2, \dots, N\}$ whose response $Y(\mathbf{x})$ lies in the intermediate subregion $F_1 = \{\mathbf{x}: Y(\mathbf{x}) > y_1\}$ (these samples are at ‘Conditional level 1’ and distributed as $q(\cdot | F_1)$). By so doing, the sample estimate of $P(F_1)$ is equal to p_0 . Starting from each one of these samples, Markov Chain Monte Carlo (MCMC) simulation is used to generate $(1 - p_0)N$ additional conditional samples in the intermediate subregion $F_1 = \{\mathbf{x}: Y(\mathbf{x}) > y_1\}$, so that there are a total of N conditional samples $\{\mathbf{x}_1^k: k = 1, 2, \dots, N\} \in F_1$. Then, the intermediate threshold value y_2 is chosen as the $(1 - p_0)N^{\text{th}}$ value in the ascending list of $\{Y(\mathbf{x}_1^k): k = 1, 2, \dots, N\}$ to define $F_2 = \{\mathbf{x}: Y(\mathbf{x}) > y_2\}$. The p_0N samples lying in F_2 function as ‘seeds’ for sampling $(1 - p_0)N$ additional conditional samples lying in F_2 , making up a total of N conditional samples $\{\mathbf{x}_2^k: k = 1, 2, \dots, N\} \in F_2$ (these samples are at ‘Conditional level 2’ and distributed as $q(\cdot | F_2)$). By so doing, the sample estimate of $P(F_2|F_1)$ is still equal to p_0 . This procedure is repeated until the samples lying in the intermediate subregion $F_{m-1} = \{\mathbf{x}: Y(\mathbf{x}) > y_{m-1}\}$ are generated to yield $y_m > y$ as the $(1 - p_0)N^{\text{th}}$ value in the ascending list of $\{Y(\mathbf{x}_{m-1}^k): k = 1, 2, \dots, N\}$. Then, the conditional probability $P_m = P(F_m|F_{m-1})$ is estimated by $\hat{P}_m = N_m / N$ where N_m is the number of samples among $\{Y(\mathbf{x}_{m-1}^k): k = 1, 2, \dots, N\}$ that lie in the failure region $F = F_m$, i.e., $N_m = \text{Dim}\{Y(\mathbf{x}_{m-1}^k) > \alpha_Y\}$. Finally, the failure probability $P(F)$ is computed as follows:

$$P(F) = P(F_1) \prod_{i=2}^m P(F_i | F_{i-1}) \approx \hat{P}(F) = p_0^{m-1} \cdot \frac{N_m}{N} \quad (2)$$

The superior efficiency of SS with respect to standard MCS in the estimation of small failure probabilities has been widely demonstrated in the open literature: the interested reader may refer to [60], [61] for mathematical details, to [67], [72]-[76] for illustrative applications to high-dimensional (i.e., $n \geq 100$) structural reliability problems and to [35] for an application to the functional failure analysis of a T-H passive system.

3.1.2 Sensitivity analysis by SS

Two approaches of literature are here considered for performing sensitivity analyses by SS within the framework of failure probability assessment: the first one is *local* and embraces the concept of *reliability sensitivity* (Section 3.1.2.1); the second one is *global* and employs the conditional

samples generated by MCMC simulation to obtain the *entire distribution* of the system failure probability conditional on the values of the individual uncertain input parameters (Section 3.1.2.2).

3.1.2.1 Local reliability sensitivity analysis

In the framework of *reliability sensitivity*, the sensitivity to a given uncertain input variable is defined as the partial derivative of the system failure probability with respect to the parameters (e.g., the mean, the standard deviation, ...) of the probability distribution of the input variable itself [65], [70], [77]-[79].

Based on (2), the partial derivative $\partial P(F)/\partial \varphi_{x_j}$ of the failure probability $P(F)$ with respect to a generic distribution parameter φ_{x_j} (e.g., the mean μ_{x_j} , the standard deviation σ_{x_j} , ...) of the uncertain input variable $x_j, j = 1, 2, \dots, n_i$, can be expressed as

$$\frac{\partial P(F)}{\partial \varphi_{x_j}} = \frac{P(F)}{P(F_1)} \frac{\partial P(F_1)}{\partial \varphi_{x_j}} + \sum_{i=2}^m \frac{P(F)}{P(F_i | F_{i-1})} \frac{\partial P(F_i | F_{i-1})}{\partial \varphi_{x_j}}, j = 1, 2, \dots, n_i. \quad (3)$$

It can be demonstrated (through lengthy mathematical operations here not reported for brevity sake) that the SS estimators $\partial \hat{P}(F_1)/\partial \varphi_{x_j}, j = 1, 2, \dots, n_i$, and $\partial \hat{P}(F_i | F_{i-1})/\partial \varphi_{x_j}, j = 1, 2, \dots, n_i, i = 1, 2, \dots, m$, for $\partial P(F_1)/\partial \varphi_{x_j}$ and $\partial P(F_i | F_{i-1})/\partial \varphi_{x_j}$, respectively, are [65]:

$$\frac{\partial \hat{P}(F_1)}{\partial \varphi_{x_j}} = \frac{1}{N} \sum_{k=1}^N \left[\frac{I_{F_1}(\mathbf{x}_0^k)}{q(\mathbf{x}_0^k)} \frac{\partial q(\mathbf{x}_0^k)}{\partial \varphi_{x_j}} \right] \quad (4)$$

$$\frac{\partial \hat{P}(F_i | F_{i-1})}{\partial \varphi_{x_j}} = \frac{1}{N} \sum_{k=1}^N \left\{ I_{F_i}(\mathbf{x}_{i-1}^k) \left[\frac{1}{q(\mathbf{x}_{i-1}^k)} \frac{\partial q(\mathbf{x}_{i-1}^k)}{\partial \varphi_{x_j}} - \sum_{l=1}^{i-1} \frac{1}{\hat{P}(F_l | F_{l-1})} \frac{\partial \hat{P}(F_l | F_{l-1})}{\partial \varphi_{x_j}} \right] \right\}. \quad (5)$$

where $\mathbf{x}_0^k$ and $\mathbf{x}_{i-1}^k$ are defined in Section 3.1.1. Substituting (4) and (5) into (3), the estimator $\partial \hat{P}(F)/\partial \varphi_{x_j}$ for $\partial P(F)/\partial \varphi_{x_j}$ is readily obtained. For further mathematical details, the interested reader may refer to [65], from which equations (3)-(5) are taken.

3.1.2.2 Global sensitivity analysis based on conditional samples

The Markov chain samples generated by SS can be used to draw information about the most probable configurations of uncertain input parameters/variables that will occur in the case of system failure [66], [67]. In particular, comparing the probability density function $q(x_j | F)$ of the uncertain parameter $x_j, j = 1, 2, \dots, n_i$, conditional to the occurrence of system failure F , with the unconditional probability density function $q(x_j)$, the importance of parameter x_j in determining system failure can be inferred. Formally, for any given value of x_j the Bayes' theorem reads

$$P(F | x_j) = \frac{q(x_j | F)}{q(x_j)} P(F), j = 1, 2, \dots, n_i \quad (6)$$

so that $P(F | x_j)$ is insensitive to x_j when $q(x_j | F) \sim q(x_j)$, i.e. when the conditional probability density function $q(x_j | F)$ is similar in shape to the PDF $q(x_j)$ [60], [61], [66], [67]. Intuitively, the sensitivity of the failure probability of the system to its uncertain input parameters/variables can thus be studied by examining the change of the sample distributions $q(x_j|F_i)$, $j = 1, 2, \dots, n_i$, $i = 1, 2, \dots, m$, at different conditional levels F_i , $i = 1, 2, \dots, m$: in particular, the more significant the change (or, in other words, the more significant the difference between the shapes of the sample distributions $q(x_j|F_i)$ and the shape of the original distribution $q(x_j)$), the larger the sensitivity of the system performance (and of the failure probability) to the corresponding uncertain parameter/variable x_j , $j = 1, 2, \dots, n_i$. See [34], [61], [66] and [67] for illustrative applications of this intuitive approach.

The information contained in the empirical conditional distributions $q(x_j|F_i)$, $j = 1, 2, \dots, n_i$, $i = 1, 2, \dots, m$, generated by MCMC simulation can then be used to *refine* the intuitive sensitivity information described above by obtaining the *entire distribution* of the system failure probability conditional on the values of the individual uncertain input parameters, i.e. $P(F|x_j)$, according to (10): this information is relevant because it quantifies how the failure probability $P(F)$ of the system would change if the value of the uncertain parameter x_j were set to a given value (e.g., if its epistemic uncertainty were reduced).

This approach can be considered global in the sense of [46] (see the Introduction) because during the SS procedure i) the *whole* range of variability of each uncertain input variable x_j , $j = 1, 2, \dots, n_i$, is “searched” through subsequent MCMC simulations to produce the *entire distribution* of the system failure probability conditional on the values of each individual uncertain input variable, i.e. $P(F|x_j)$, $j = 1, 2, \dots, n_i$; ii) the conditional samples of *each* uncertain input variable x_j , $j = 1, 2, \dots, n_i$, distributed as $q(x_j|F_i)$, $j = 1, 2, \dots, n_i$, $i = 1, 2, \dots, m$, are generated by MCMC while *all* other uncertain input parameters are “varying” (i.e., are being sampled) as well.

3.2 Line Sampling

Line Sampling (LS) is a probabilistic simulation method for efficiently computing small failure probabilities. It was originally developed for the reliability analysis of complex structural systems [62]. The underlying idea is to employ *lines* instead of random *points* in order to probe the failure domain of the high-dimensional system under analysis [63]. The Line Sampling (LS) algorithm and its use for sensitivity analysis are briefly illustrated in Sections 3.2.1 and 3.2.2, respectively.

3.2.1 The algorithm

In extreme synthesis, the computational steps of the LS algorithm are [63], [76]:

1. From the original multidimensional joint probability density function $q(\cdot): \mathcal{R}^n \rightarrow [0, \infty)$, sample N_T vectors $\{\mathbf{x}^k : k=1, 2, \dots, N_T\}$, with $\mathbf{x}^k = \{x_1^k, x_2^k, \dots, x_j^k, \dots, x_{n_i}^k\}$.
2. Transform the N_T sample vectors $\{\mathbf{x}^k : k=1, 2, \dots, N_T\}$ defined in the original (i.e., physical) space into N_T samples $\{\boldsymbol{\theta}^k : k=1, 2, \dots, N_T\}$ defined in the standard normal space; also the PFs $g_x(\cdot)$ defined in the physical space have to be transformed into $g_\theta(\cdot)$ in the standard normal space.
3. In the standard normal space, determine the *unit* important direction $\boldsymbol{\alpha} = \{\alpha_1, \alpha_2, \dots, \alpha_j, \dots, \alpha_{n_i}\}^T$ (hereafter also called “important unit vector” or “important direction”) pointing towards the failure domain F of interest.
4. Reduce the problem of computing the high-dimensional failure probability integral (1) to a number of conditional one-dimensional problems, solved along the “important direction” $\boldsymbol{\alpha}$ in the standard normal space: in particular, estimate N_T conditional “one-dimensional” failure probabilities $\{\hat{P}(F)^{1D,k} : k=1, 2, \dots, N_T\}$, corresponding to each one of the standard normal samples $\{\boldsymbol{\theta}^k : k=1, 2, \dots, N_T\}$ obtained in step 2. above (see [63], [76] for details).
5. Compute the unbiased estimator $\hat{P}(F)$ for the failure probability $P(F)$ and its variance $\sigma^2[\hat{P}(F)]$ as:

$$\hat{P}(F) = 1/N_T \cdot \sum_{k=1}^{N_T} \hat{P}(F)^{1D,k}, \quad (7)$$

$$\sigma^2[\hat{P}(F)] = 1/N_T(N_T - 1) \cdot \sum_{k=1}^{N_T} (\hat{P}(F)^{1D,k} - \hat{P}(F))^2. \quad (8)$$

The LS method has been shown to significantly reduce the variance (8) of the estimator (7) of the failure probability integral (1) [35], [36], [62], [63], [68]-[71], [76], [80]-[83].

It is worth noting that the LS technique outlined above can be applied also to systems with *multiple* failure regions $F^l = \{\mathbf{x} : g_x^l(\mathbf{x}) > 0\} = \{\boldsymbol{\theta} : g_\theta^l(\boldsymbol{\theta}) > 0\}$, $l = 1, 2, \dots, N_F$. These multiple failure regions $F^l = \{\mathbf{x} : g_x^l(\mathbf{x}) > 0\} = \{\boldsymbol{\theta} : g_\theta^l(\boldsymbol{\theta}) > 0\}$, $l = 1, 2, \dots, N_F$, can be identified by i) enumerating *all* (or, at least, the most *likely* and *relevant*) *failure modes* of the system² and ii) associating *each* failure

² To identify the relevant failure modes of the system, well-structured and commonly used *qualitative* hazard analyses may be employed, e.g., Failure Mode and Effect Analysis (FMEA) and HAZard and OPERability (HAZOP) analysis

mode with *one* failure region $F^l = \{\mathbf{x} : g_x^l(\mathbf{x}) > 0\} = \{\boldsymbol{\theta} : g_\theta^l(\boldsymbol{\theta}) > 0\}$, $l = 1, 2, \dots, N_F$. Only for illustration purposes, let us suppose that the system of interest has $N_F = 2$ failure modes, e.g., it fails when either performance function $Y_1(\mathbf{x})$ exceeds threshold α_{Y_1} or performance function $Y_2(\mathbf{x})$ exceeds threshold α_{Y_2} : in such a case, the corresponding failure regions F^1 and F^2 can be identified as $F^1 = \{\mathbf{x} : g_x^1(\mathbf{x}) > 0\} = \{\mathbf{x} : Y_1(\mathbf{x}) - \alpha_{Y_1} > 0\}$ and $F^2 = \{\mathbf{x} : g_x^2(\mathbf{x}) > 0\} = \{\mathbf{x} : Y_2(\mathbf{x}) - \alpha_{Y_2} > 0\}$, respectively. When multiple failure regions are present, an “important direction” $\boldsymbol{\alpha}^l$ has to be identified for *each* failure region F^l , $l = 1, 2, \dots, N_F$. Then, each one of the standard normal samples $\{\boldsymbol{\theta}^k : k = 1, 2, \dots, N_T\}$ obtained in step 2. of the LS algorithm has to be associated in a *unique* manner to *one* of the identified directions; the method proposed by Schueller et al. (2004) [80] can be employed to this aim: the interested reader is referred to the original reference for details.

Those samples among $\{\boldsymbol{\theta}^k : k = 1, 2, \dots, N_T\}$ that belong to the l^{th} failure region F^l , $l = 1, 2, \dots, N_F$, are then used to compute the estimate $\hat{P}(F^l)$ of the l^{th} failure probability $P(F^l)$ by performing steps 4. and 5. above of the LS algorithm.

Finally, if the failure regions F^l , $l = 1, 2, \dots, N_F$, are *disconnected* (i.e., *not overlapping*), the estimate $\hat{P}(F)$ of the failure probability $P(F)$ is simply given by the sum of the estimates $\hat{P}(F^l)$ of the individual failure probabilities $P(F^l)$, $l = 1, 2, \dots, N_F$:

$$\hat{P}(F) = \sum_{l=1}^{N_F} \hat{P}(F^l). \quad (9)$$

On the contrary, if the failure regions F^l , $l = 1, 2, \dots, N_F$, are *overlapping*, some modifications to the procedure here outlined are required to ensure that the estimates $\hat{P}(F^l)$, $l = 1, 2, \dots, N_F$, do not contain contributions from other failure domains. However, since the analysis of this situation goes beyond the scopes of the present paper, mathematical details are not reported here for brevity: the interested reader is referred to [70], [80].

As a final remark, notice that the efficiency of the LS method depends on the accurate determination of the important direction $\boldsymbol{\alpha}$ (step 3. of the algorithm above) [36], [62], [63], [83]. In this work, the method based on the normalized “center of mass” of the failure domain F has been employed [62]. In particular, A point $\boldsymbol{\theta}^0$ is taken in the failure domain F . Subsequently, $\boldsymbol{\theta}^0$ is used as the initial point of a Markov chain which lies entirely in the failure domain F . For that purpose, a

[11], [13]; when possible, the qualitative information provided by the hazard identification methods mentioned above may be completed by numerical results produced by *quantitative* techniques, such as the optimum criterion method [84] and stochastic limit analysis [70] originally developed within the field of structural reliability.

Metropolis-Hastings algorithm is employed to generate a sequence of N_s points $\{\theta^u : u = 1, 2, \dots, N_s\}$ lying in the failure domain F [64]. The unit vectors $\theta^u / \|\theta^u\|_2$, $u = 1, 2, \dots, N_s$, are then averaged in order to obtain the LS important unit vector as $\alpha = \frac{1}{N_s} \cdot \sum_{u=1}^{N_s} \theta^u / \|\theta^u\|_2$. This direction provides a good “map” of the failure domain and thus it provides in principle a realistic indication of the actual location of the failure domain and, thus, a reliable estimate for the LS important direction α .

3.2.2 Local reliability sensitivity analysis by LS

The important unit vector $\alpha = \{\alpha_1, \alpha_2, \dots, \alpha_j, \dots, \alpha_{n_i}\}$ is determined to point towards the failure domain F of interest (Section 3.2.1). As such, the vector α tells which combinations of parameter variations contribute most to failure and thus gives an idea of the relative importance of the uncertain parameters $\{\theta_j : j = 1, 2, \dots, n\}$ in determining the failure of the system under analysis [63]. For example, in the situation depicted in Figure 1, left, the system would be driven to failure much more effectively by an increase in Parameter 2 rather than by an increase in Parameter 1; on the contrary, in the situation represented in Figure 1, right, an increase in Parameter 1 would be much more important in determining system failure than an increase in Parameter 2. In this view, the *sensitivity* of the passive system performance to the individual uncertain inputs can be studied by comparing the magnitudes of the components of α : see [35] for a preliminary application of this concept to the model of a nuclear passive system.

Figure 1

This intuitive concept was put in a formal framework in [68]-[71]: in particular, embracing the concept of reliability sensitivity, the authors derived formal expressions for the LS estimators $\partial \hat{P}(F) / \partial \mu_{\theta_j}$ and $\partial \hat{P}(F) / \partial \sigma_{\theta_j}$ of the partial derivatives $\partial P(F) / \partial \mu_{\theta_j}$ and $\partial P(F) / \partial \sigma_{\theta_j}$ of the system failure probability $P(F)$ with respect to the parameters (i.e., the mean μ_{θ_j} and the standard deviation σ_{θ_j}) of the normal probability distributions of the uncertain input variables $\{\theta_j : j = 1, 2, \dots, n_i\}$ in the standard normal space. Without going into mathematical details, it can be demonstrated that $\partial \hat{P}(F) / \partial \mu_{\theta_j} \propto \alpha_j$ and $\partial \hat{P}(F) / \partial \sigma_{\theta_j} \propto (\alpha_j)^2$ [68]-[71], which confirms the intuition that the sensitivity of the system failure probability $P(F)$ to a given uncertain input variable θ_j is *proportional* to the *magnitude* of the corresponding component α_j of the important vector α .

Finally, based on (15), it is straightforward to show that in the case of multiple, non-overlapping failure regions F^l , $l = 1, 2, \dots, N_F$, $\partial \hat{P}(F)/\partial \mu_{\theta_j} = \sum_{l=1}^{N_F} \partial \hat{P}(F^l)/\partial \mu_{\theta_j}$ and $\partial \hat{P}(F)/\partial \sigma_{\theta_j} = \sum_{l=1}^{N_F} \partial \hat{P}(F^l)/\partial \sigma_{\theta_j}$, with $\partial \hat{P}(F^l)/\partial \mu_{\theta_j} \propto \alpha_j^l$ and $\partial \hat{P}(F^l)/\partial \sigma_{\theta_j} \propto (\alpha_j^l)^2$ [68]-[71].

4 Case study 1: Ishigami function

In this Section, the case study involving the well-known Ishigami function [1] is illustrated: in particular, in Section 4.1, few details about the model are provided; in Section 4.2, the results of the application of the SS and LS methods for the sensitivity analysis of the model of Section 4.1 are illustrated.

4.1 The model

The Ishigami function (20) [1] is frequently adopted as a benchmark in sensitivity studies due to its challenging properties, i.e., nonlinearity, non-monotonicity and presence of interactions between the uncertain input variables [39], [41], [53], [85]:

$$Y(\mathbf{x}) = Y(x_1, x_2, x_3) = \sin(x_1) + 7 \sin^2(x_2) + 0.1x_3^4 \sin(x_1) \quad (10)$$

where x_1 , x_2 and x_3 are uncertain input variables following a uniform distribution on $[-\pi, +\pi]$.

Since the main objective of the present paper is to perform the sensitivity analysis of the performance (or, in other word, the functional failure probability) of a nuclear passive system, the Ishigami function $Y(\mathbf{x})$ (20) is artificially modified to this aim. In particular, using the notation of Section 2, $Y(\mathbf{x})$ (20) is taken as the indicator of the performance of a fictitious passive system and an hypothetical failure threshold $\alpha_Y = 16.5$ is correspondingly introduced: this leads to define the associated Performance Function (PF) or Limit State Function (LSF) $g_x(\mathbf{x})$ as

$$g_x(\mathbf{x}) = Y(\mathbf{x}) - \alpha_Y = \sin(x_1) + 7 \sin^2(x_2) + 0.1x_3^4 \sin(x_1) - 16.5. \quad (11)$$

Then, the fictitious passive system characterized by the LSF (21) is supposed to fail when its LSF becomes larger than or equal to 0, i.e., $g_x(\mathbf{x}) \geq 0$. The true (i.e., reference) probability $P(F)$ of the failure event $F = \{\mathbf{x}: g_x(\mathbf{x}) \geq 0\}$ is $5.566 \cdot 10^{-4}$, obtained by standard MCS with $N_T = 500000$ samples drawn.

Figure 2 shows the failure region $F = \{\mathbf{x}: g_x(\mathbf{x}) \geq 0\}$ (dark areas) associated to the LSF $g_x(\mathbf{x})$ (21) based on the Ishigami function $Y(\mathbf{x})$ (20) in the space of the uncertain input variables $\{x_j; j = 1, 2, 3\}$. It is interesting to note that the failure region $F = \{\mathbf{x}: g_x(\mathbf{x}) \geq 0\}$ is composed by four

disconnected (i.e., not overlapping) failure regions $\{F^l: l = 1, 2, 3, 4\}$, i.e., $F = F^1 \cup F^2 \cup F^3 \cup F^4$. The four disconnected failure regions $\{F^l: l = 1, 2, 3, 4\}$ are defined as follows:

$$F^1 = \{\mathbf{x} : x_1 \in [1.1017, 2.0250], x_2 \in [-1.9963, -1.1514], x_3 \in [-3.1414, -3.0390]\} \quad (12)$$

$$F^2 = \{\mathbf{x} : x_1 \in [1.1017, 2.0250], x_2 \in [1.1514, 1.9963], x_3 \in [-3.1414, -3.0390]\} \quad (13)$$

$$F^3 = \{\mathbf{x} : x_1 \in [1.1017, 2.0250], x_2 \in [1.1514, 1.9963], x_3 \in [3.0390, 3.1414]\} \quad (14)$$

$$F^4 = \{\mathbf{x} : x_1 \in [1.1017, 2.0250], x_2 \in [-1.9963, -1.1514], x_3 \in [3.0390, 3.1414]\} \quad (15)$$

Notice that (22)-(25) are characterized by important *symmetry* properties: in particular, in failure regions F^1 and F^4 parameter x_2 ranges between -1.9963 and -1.1514 , whereas in failure regions F^2 and F^3 it symmetrically ranges between 1.1514 and 1.9963 ; further, in failure regions F^1 and F^2 parameter x_3 ranges between -3.1414 and -3.0390 , whereas in failure regions F^3 and F^4 it symmetrically ranges between 3.0390 and 3.1414 ³.

Figure 2

4.2 Application

In this Section, the SS and LS methods are applied for i) the estimation of the failure probability $P(F)$ (Section 4.2.1) and ii) the sensitivity analysis of the performance (Section 4.2.2) of the synthetic passive system characterized by the LSF $g_x(\mathbf{x})$ (21) based on the Ishigami function $Y(\mathbf{x})$ (20).

4.2.1 Failure probability estimation

For completeness and only for illustration purposes, Table 1 reports the values of the estimates $\hat{P}(F)$ of the failure probability $P(F)$ obtained by SS with $N_T = 3700$ samples (i.e., $m = 4$ simulation levels, each with $N = 1000$ samples) and LS with $N_T = 3700$; for comparison purposes, the results obtained by standard MCS with the same number $N_T = 3700$ of samples are also presented. In order to evaluate the *accuracy* of the estimates, a “true” value of the failure probability $P(F)$ is also reported in Table 1 for reference (i.e., $P(F) = 5.566 \cdot 10^{-4}$); as mentioned above, this has been obtained by standard MCS with a very large number N_T (i.e., $N_T = 500000$) of simulations. Finally, in order to evaluate the *precision* of the estimates, the standard deviation $\hat{\sigma}[\hat{P}(F)]$ of $\hat{P}(F)$ is also computed.

³ It is worth noting that due to the simplicity of the problem failure regions $\{F^l: l = 1, 2, 3, 4\}$ (22)-(25) have been determined *analytically* by straightforward analysis of performance function (20).

Table 1

As expected, LS outperforms the other methods in terms of *accuracy* (i.e., the LS failure probability estimate $\hat{P}(F)$ is *closer* to the true value $P(F)$ than those of the other methods) and *precision* (i.e., the standard deviation $\hat{\sigma}[\hat{P}(F)]$ of $\hat{P}(F)$ is *lower* than those of the other methods) of the failure probability estimates.

4.2.2 Sensitivity analysis results

The *same* $N_T = 3700$ samples used in the previous Section 4.2.1 to estimate the failure probability of the synthetic passive system of Section 4.1 are here employed for studying the sensitivity of its performance (i.e., of its failure probability) to the uncertain input variables. In Section 4.2.2.1, the results obtained by the SS- and LS-based *local* reliability sensitivity approaches of Sections 3.1.2.1 and 3.2.2, respectively, are shown. In Section 4.2.2.2, the results obtained by the SS-based *global* approach of Section 3.1.2.2 are presented; in addition, the sensitivity insights provided by the SS-based method are compared to those produced by Sobol indices.

4.2.2.1 Local reliability sensitivity results

Since the results produced by the LS method are obtained in the standard normal space by construction (see Sections 3.2.1 and 3.2.2 for details), for fair comparison with the other methods, the uncertain input variables $\{x_j; j = 1, 2, 3\}$ in (21) have been transformed into $\{\theta_j; j = 1, 2, 3\}$ in the standard normal space and also the system LSF $g_x(\mathbf{x})$ (21) has been transformed into $g_\theta(\boldsymbol{\theta})$ in the standard normal space: thus, the partial derivatives of the system failure probability with respect to the parameters of the distributions of the uncertain input variables are calculated in the standard normal space for *all* the simulation methods considered.

Table 2 reports the values of the estimates $\partial\hat{P}(F)/\partial\mu_{\theta_j}$ and $\partial\hat{P}(F)/\partial\sigma_{\theta_j}$ of the partial derivatives $\partial P(F)/\partial\mu_{\theta_j}$ and $\partial P(F)/\partial\sigma_{\theta_j}$ of the failure probability $P(F)$ with respect to the mean μ_{θ_j} and the standard deviation σ_{θ_j} of the distributions of the uncertain input parameters $\{\theta_j; j = 1, 2, 3\}$, computed by standard MCS, SS and LS with $N_T = 3700$ samples. Notice that in the present implementation of the LS technique we suppose that the analyst does not recognize the presence of four disconnected failure regions and, consequently, he/she identifies *one single* important vector $\boldsymbol{\alpha}$ by MCMC simulation (Section 3.2.1). In particular, a point $\boldsymbol{\theta}^0$ is chosen in the failure domain F ; subsequently, a sequence of $N_s = 1000$ points $\{\boldsymbol{\theta}^u; u = 1, 2, \dots, N_s\}$ lying in the failure domain F is generated by MCMC; then, since by hypothesis the analyst does not realize that the points

$\{\theta^u : u = 1, 2, \dots, N_s\}$ “belong” to four disconnected failure regions, he/she *averages* the unit vectors $\theta^u / \|\theta^u\|_2$, $u = 1, 2, \dots, N_s$, to obtain the *unique* important vector $\alpha = [0.2456, 1.994 \cdot 10^{-3}, -2.434 \cdot 10^{-5}]$. “True” values of $\partial P(F) / \partial \mu_{\theta_j}$ and $\partial P(F) / \partial \sigma_{\theta_j}$ are also reported in Table 2 for reference: as before, these have been obtained by standard MCS with a very large number N_T (i.e., $N_T = 500000$) of simulations. The ranking of the uncertain input parameters $\{\theta_j : j = 1, 2, 3\}$ based on the estimates $\partial \hat{P}(F) / \partial \mu_{\theta_j}$ and $\partial \hat{P}(F) / \partial \sigma_{\theta_j}$ is shown in parentheses.

Table 2

Considering, e.g., the (reference) results obtained by standard MCS with $N_T = 500000$ samples, one would infer that:

- moving the mean μ_{θ_1} of the probability distribution of θ_1 from its nominal value (i.e., 0) towards positive values *increases* the failure probability $P(F)$ of the system (actually, the sign of $\partial \hat{P}(F) / \partial \mu_{\theta_1}$ is *positive*). This information is *coherent* with the “configuration” of the four failure regions $\{F^l : l = 1, 2, 3, 4\}$ (22)-(25): actually, in case of system failure, parameter x_1 is found to range between the values 1.1017 and 2.0250 (which are both *larger* than the nominal value of the mean of the probability distribution of x_1 , i.e., 0);
- moving the mean μ_{θ_2} (μ_{θ_3}) of the probability distribution of θ_2 (θ_3) from its nominal value (i.e., 0) is *much less effective* than moving μ_{θ_1} in increasing (decreasing) the failure probability $P(F)$ of the system: actually, the magnitude of the absolute value of $\partial \hat{P}(F) / \partial \mu_{\theta_2}$ ($\partial \hat{P}(F) / \partial \mu_{\theta_3}$) is about one hundred times lower than that of $\partial \hat{P}(F) / \partial \mu_{\theta_1}$;
- in order to effectively drive the system to failure (or, in other words, to increase its failure probability $P(F)$) the mean μ_{θ_2} (μ_{θ_3}) of the probability distribution of θ_2 (θ_3) have to be moved from its nominal value (i.e., 0) towards positive (negative) values: actually, the sign of $\partial \hat{P}(F) / \partial \mu_{\theta_2}$ ($\partial \hat{P}(F) / \partial \mu_{\theta_3}$) is *positive* (*negative*). However, this information is *wrong* or, at least, *not complete* if referred to the “configuration” of the four failure regions $\{F^l : l = 1, 2, 3, 4\}$ (22)-(25): actually, in case of system failure parameter x_2 may range *either* between the values 1.1514 and 1.9963 (which are both *larger* than the nominal value of the mean of the probability distribution of x_2 , i.e., 0) *or* between the values -1.9963 and -1.1514 (which instead are both *smaller* than the nominal value of the mean of the probability distribution of x_2 , i.e., 0). Similar considerations hold for parameter θ_3 .

This latter consideration highlights the inadequacy of the local reliability sensitivity approach when applied to problems presenting multiple failure regions. Actually, the reason behind the inappropriateness or incompleteness of the information provided by the results in Table 2 is readily explained by the symmetry properties characterizing the four failure regions $\{F^l: l = 1, 2, 3, 4\}$ (22)-(25): actually, as already explained in Section 4.1, in failure regions F^1 and F^4 parameter x_2 ranges between -1.9963 and -1.1514 , whereas in failure regions F^2 and F^3 it symmetrically ranges between 1.1514 and 1.9963 ; further, in failure regions F^1 and F^2 parameter x_3 ranges between -3.1414 and -3.0390 , whereas in failure regions F^3 and F^4 it symmetrically ranges between 3.0390 and 3.1414 . As a consequence, in estimating $\partial P(F)/\partial \mu_{\theta_2}$ and $\partial P(F)/\partial \mu_{\theta_3}$ the positive and negative contributions associated to the failure regions symmetric with respect to the origin of the input parameter space “cancel out”: this produces estimates $\partial \hat{P}(F)/\partial \mu_{\theta_2}$ and $\partial \hat{P}(F)/\partial \mu_{\theta_3}$ very close to zero (e.g., in the present case both $\partial \hat{P}(F)/\partial \mu_{\theta_2}$ and $\partial \hat{P}(F)/\partial \mu_{\theta_3}$ are approximately 10^{-3} and 10^{-5} , respectively).

This problem can be overcome by employing the LS method with four different important directions $\{\alpha^l: l = 1, 2, 3, 4\}$ pointing towards the four failure regions $\{F^l, l = 1, 2, 3, 4\}$ (22)-(25): in particular, $\alpha_1 = [0.2441, -0.2462, -0.9379]$, $\alpha_2 = [0.2465, 0.2460, -0.9374]$, $\alpha_3 = [0.2468, 0.2497, 0.9363]$ and $\alpha_4 = [0.2448, -0.2417, 0.9389]$ have been identified by MCMC simulation with $N_s = 2000$ samples (see Section 3.2.1). This allows to quantify *separately* the contributions of the four different failure regions, i.e., $\{\partial \hat{P}(F^l)/\partial \mu_{\theta_j} : l = 1, 2, 3, 4\}$ and $\{\partial \hat{P}(F^l)/\partial \sigma_{\theta_j} : l = 1, 2, 3, 4\}$, $j = 1, 2, 3$, to the estimates $\partial \hat{P}(F)/\partial \mu_{\theta_j}$ and $\partial \hat{P}(F)/\partial \sigma_{\theta_j}$, $j = 1, 2, 3$. The corresponding results are shown in Table 3.

Table 3

It can be seen that contrary to the (erroneous) indications provided by the results in Table 2, variable θ_3 is the *most effective* in driving the system to failure: indeed, the absolute values of $\{\partial \hat{P}(F^l)/\partial \mu_{\theta_3} : l = 1, 2, 3, 4\}$ are about ten times larger than those of $\{\partial \hat{P}(F^l)/\partial \mu_{\theta_1} : l = 1, 2, 3, 4\}$ and $\{\partial \hat{P}(F^l)/\partial \mu_{\theta_2} : l = 1, 2, 3, 4\}$; further, variables θ_1 and θ_2 are almost *equally effective* in driving the

system to failure: indeed, the magnitude of the absolute values of $\{\partial \hat{P}(F^l)/\partial \mu_{\theta_l} : l = 1, 2, 3, 4\}$ and $\{\partial \hat{P}(F^l)/\partial \mu_{\theta_2} : l = 1, 2, 3, 4\}$ is about the same.

4.2.2.2 Global sensitivity results

The results obtained in the previous Section 4.2.2.1 by the local reliability sensitivity approaches are compared here to those produced by the global SS-based sensitivity approach of Section 3.1.2.2.

Figure 3 shows the distribution of the system failure probability conditional on the values of the individual uncertain input parameters, i.e. $P(F|x_1)$ (top, left), $P(F|x_2)$ (top, right) and $P(F|x_3)$ (bottom) obtained according to (10). This information is relevant because it quantifies how the failure probability $P(F)$ of the system would change if the value of the uncertain parameter x_j were set to a given value (e.g., if its uncertainty were reduced): for example, fixing x_1 to 1.5 would result in $P(F) \approx 6 \cdot 10^{-3}$, fixing x_2 to -1.5 or $+1.5$ would result in $P(F) \approx 4 \cdot 10^{-3}$, whereas fixing x_3 to about -3 or $+3$ would result in $P(F) \approx 8 \cdot 10^{-3}$.

In addition, the shape of the distributions $P(F|x_j)$, $j = 1, 2, 3$, obviously reflects the “structure” of the four failure regions $\{F^l, l = 1, 2, 3, 4\}$ (22)-(25): for example, the distribution $P(F|x_1)$ takes values different from zero when x_1 approximately ranges between $+1$ and $+2$ (see (22)-(25)); the distribution $P(F|x_2)$ takes values different from zero when x_2 approximately ranges between -2 and -1 (see (22) and (25)) or between $+1$ and $+2$ (see (23) and (24)); finally, the distribution $P(F|x_3)$ takes values different from zero when x_3 assumes values around -3 (see (22) and (23)) or $+3$ (see (24) and (25)).

Figure 3

Finally, the results shown in Figure 3 can be used to rank the uncertain input variables $\{x_j; j = 1, 2, 3\}$ according to their effectiveness in driving the system to failure (or, in other words, to quantify the importance of the variability of the individual uncertain input variables in determining the failure probability of the system). A ranking can be established on the basis of the (maximum) value assumed by the distribution $P(F|x_j)$ over the range of variability of x_j , $j = 1, 2, 3$: in particular, the larger $P(F|x_j)$, the larger the contribution of the variability of x_j in determining the system failure probability. For example, as x_1 varies in its range $[-\pi, +\pi]$, $P(F|x_1)$ takes values from 0 (minimum) to $6 \cdot 10^{-3}$ (maximum); as x_2 varies in $[-\pi, +\pi]$, $P(F|x_2)$ takes values from 0 (minimum) to $4 \cdot 10^{-3}$ (maximum); finally, as x_3 varies in $[-\pi, +\pi]$, $P(F|x_3)$ takes values from 0 (minimum) to $9 \cdot 10^{-3}$ (maximum). According to this criterion, x_3 is *much* more important than both x_1 and x_2 , whereas x_1 is *slightly* more important than x_2 in affecting the failure probability of the system.

Note that this ranking is the same as the one provided by the local reliability sensitivity approach based on LS with four different important directions (see Table 3 of Section 4.2.2.1).

Finally, for completeness the sensitivity insights provided by the SS-based global approach are also compared to those produced by first- and total-order (global) Sobol indices [45]: these indices are frequently used in the literature to identify the uncertain parameters (i.e., the uncertain inputs to a given system model) that contribute most to the *variability* of the model outputs⁴. Thus, first- and total-order Sobol indices are computed to identify those uncertain input parameters $\{x_j: j = 1, 2, 3\}$ which contribute most to the *variability* of the LSF $g_x(\mathbf{x})$ (21) based on the Ishigami function $Y(\mathbf{x})$ (20).

In more detail, by definition the first-order Sobol sensitivity index S_j^g , $j = 1, 2, 3$, quantifies the proportion of the variance of the LSF $g_x(\mathbf{x})$ (21) (i.e., the output) that can be attributed to the variance of the uncertain input variable x_j *alone*, i.e., *without* taking into account *interactions* with other input variables; on the contrary, the total-order Sobol sensitivity index S_{Tj}^g , $j = 1, 2, 3$, quantifies the proportion of the variance of the LSF $g_x(\mathbf{x})$ (21) (i.e., the output) that can be attributed to the variance of the uncertain input variable x_j taking into account the *interactions* (of *all* the *orders*) with all the other input variables [39], [44], [46].

As pointed out in [46], the sensitivity indices S_j^g and S_{Tj}^g have the advantage of being *global* because i) the effect of the *entire* distribution of the parameter whose uncertainty importance is evaluated, is considered and ii) the importance of this input parameter is evaluated with *all* other input parameters varying as well; moreover, this sensitivity index is also “model free” because its computation is independent from assumptions about the model form, such as linearity, additivity and so on. The drawback of this approach relies in the computational burden associated to its calculation: actually, thousands or millions of system model evaluations are frequently required for the evaluation of Sobol indices through Monte Carlo-based techniques [39], [46].

First- and total-order Sobol indices S_j^g and S_{Tj}^g , $j = 1, 2, 3$, are computed for the LSF $g_x(\mathbf{x})$ (21) based on the Ishigami function $Y(\mathbf{x})$ (20), by resorting to the algorithm proposed by [44]: these values obtained with $N_T = 550000$ model evaluations are reported for reference in Table 4. The ranking of the uncertain input variables is also reported in parentheses.

Table 4

⁴ Notice that the SS- and Sobol-based approaches are here compared because they are both *global*; however, their outcomes are conceptually quite different: the first one identifies the most important contributors to system failure, whereas the second one identifies the most important contributors to the variability of the model outputs.

It is interesting to note that:

- the contribution of x_3 to the variability of the LSF $g_x(\mathbf{x})$ (21) is *entirely* due to interactions with other input variables (indeed, $S_3^g = 0$ and $S_{T3}^g = 0.2490$): actually, in (21) variable x_3 does *not* appear *alone*, but *only multiplied* by the term $\sin(x_1)$;
- the contribution of x_2 to the variability of the LSF $g_x(\mathbf{x})$ (21) is *entirely* due to its variation alone and not to interactions with other input variables (indeed, $S_2^g \approx S_{T2}^g = 0.4415$): actually, in (21) variable x_2 does appear *only alone* in the term $7 \sin^2(x_2)$;
- the contribution of x_1 to the variability of the LSF $g_x(\mathbf{x})$ (21) is due *both* to its variation alone and to interactions with other input variables (indeed, $S_1^g = 0.3155$ and $S_{T1}^g = 0.5596$): actually, in (21) variable x_1 appears *both alone* in the term $\sin(x_1)$ and *multiplied* by x_3^4 in the term $0.1 x_3^4 \cdot \sin(x_1)$;
- the ranking of the uncertain input variables provided by Sobol sensitivity indices is *significantly different* from those produced by the local reliability sensitivity approach (Table 3 of Section 4.2.2.1) and by the global SS-based approach (Figure 3): for example, according to Sobol indices, parameter x_3 is the *least* important in determining the variability of the LSF $g_x(\mathbf{x})$ (21), whereas, according to the SS- and LS-based approaches, it is the *most* important in affecting the system failure probability. This leads to the conclusion that the most important contributors to the *variability* of the system model output(s) are not necessarily the most important contributors to *system failure*.

This may be due to the fact that the four failure domains of interest $\{F^l: l = 1, 2, 3, 4\}$ are *very small* with respect to the entire uncertain input space and they lie *far* from the regions characterized by the most significant variability of the model output $g_x(\mathbf{x})$ (actually, they are located at the “boundaries” of the uncertain input space, as demonstrated by (22)-(25) and, pictorially, by Figure 2): in this way, the failure domains $\{F^l: l = 1, 2, 3, 4\}$ do not “contribute” to the estimation of the Sobol indices S_j^g and S_{Tj}^g , whereas they obviously play a relevant role in the estimation of the quantities $\partial P(F)/\partial \mu_{\theta_j}$ and $P(F|x_j)$, $j = 1, 2, 3$.

5 Case study 2: nuclear passive system

In this Section, the case study concerning a nuclear passive system of literature [2] is illustrated: in Section 5.1, few details about the system model are provided; in Section 5.2, the results of the application of the SS and LS methods for the sensitivity analysis of the performance of the passive system of Section 5.1 are presented.

5.1 The model

This case study concerns the natural convection cooling in a Gas-cooled Fast Reactor (GFR) under a post-Loss Of Coolant Accident (LOCA) condition; the reactor is a 600-MW GFR cooled by helium flowing through separate channels in a silicon carbide matrix core [2].

A GFR decay heat removal configuration is shown schematically in Figure 4; in the case of a LOCA, the long-term heat removal is ensured by natural circulation in a given number N_{loops} of identical and parallel loops; only one of the N_{loops} loops is reported for clarity of the picture: the flow path of the cooling helium gas is indicated by the black arrows. The loop has been divided into $N_{sections} = 18$ sections for numerical calculation; technical details about the geometrical and structural properties of these sections are not reported here for brevity: the interested reader may refer to [2].

In the present analysis, the average core power to be removed is assumed to be 18.7 MW, equivalent to about 3% of full reactor power (600 MW): to guarantee natural circulation cooling at this power level, a pressure of 1650 kPa in the loops is required in nominal conditions. Finally, the secondary side of the heat exchanger (i.e., item 12 in Figure 4) is assumed to have a nominal wall temperature of 90 °C [2].

Figure 4

5.1.1 Uncertainties

Uncertainties affect the modeling of passive systems. There are unexpected events, e.g. the failure of a component or the variation of the geometrical dimensions and material properties, which are random in nature. This kind of uncertainty, often termed aleatory [86]-[90], is not considered in this work. Additionally, there is incomplete knowledge on the properties of the system and the conditions in which the passive phenomena develop (i.e., natural circulation). This kind of uncertainty, often termed epistemic, affects the model representation of the passive system behaviour, in terms of both (*model*) uncertainty in the hypotheses assumed and (*parameter*) uncertainty in the values of the parameters of the model [29], [55], [57].

Only epistemic uncertainties are considered in this work. Epistemic parameter uncertainties are associated to the reactor power level, the pressure in the loops after the LOCA and the cooler wall temperature; epistemic model uncertainties are associated to the correlations used to calculate the Nusselt numbers and friction factors in the forced, mixed and free convection regimes. The consideration of these uncertainties leads to the definition of a vector $\mathbf{x} = \{x_j : j = 1, 2, \dots, 9\}$ of nine

uncertain model inputs, assumed described by normal distributions of known means and standard deviations (Table 5, [2]).

Table 5

5.1.2 Failure criteria of the T-H passive system

The passive decay heat removal system of Figure 4 fails to provide its safety function when the temperature of the coolant helium leaving the core (item 4 in Figure 4) exceeds either 1200 °C in the hot channel or 850 °C in the average channel: these values are expected to limit the fuel temperature to levels which prevent excessive release of fission gases and high thermal stresses in the cooler (item 12 in Figure 4) and in the stainless steel cross ducts connecting the reactor vessel and the cooler (items from 6 to 11 in Figure 4) [2]. Denoting by $T_{out,core}^{hot}(\mathbf{x})$ and $T_{out,core}^{avg}(\mathbf{x})$ the coolant outlet temperatures in the hot and average channels, respectively, the system failure event F can be written as follows:

$$F = \{\mathbf{x} : T_{out,core}^{hot}(\mathbf{x}) > 1200\} \cup \{\mathbf{x} : T_{out,core}^{avg}(\mathbf{x}) > 850\}. \quad (16)$$

Notice that, in the notation of Section 2, $T_{out,core}^{hot}(\mathbf{x}) = y_1(\mathbf{x})$ and $T_{out,core}^{avg}(\mathbf{x}) = y_2(\mathbf{x})$ are the $n_o = 2$ outputs of the T-H model.

The failure region F (26) is then condensed into a single performance indicator $Y(\mathbf{x})$, leading to the definition of a single-output Limit State Function (LSF) or Performance Function (PF) $g_x(\cdot)$ (Section 2). The system performance indicator $Y(\mathbf{x})$ is defined as

$$Y(\mathbf{x}) = \max\left\{\frac{T_{out,core}^{hot}(\mathbf{x})}{1200}, \frac{T_{out,core}^{avg}(\mathbf{x})}{850}\right\} = \max\left\{\frac{y_1(\mathbf{x})}{1200}, \frac{y_2(\mathbf{x})}{850}\right\} \quad (17)$$

so that the failure region F becomes specified as:

$$F = \{\mathbf{x} : Y(\mathbf{x}) > 1\}. \quad (18)$$

In the notation of Section 2, the failure threshold α_Y is then equal to one and the system LSF in (1) is written as

$$g_x(\mathbf{x}) = Y(\mathbf{x}) - \alpha_Y = Y(\mathbf{x}) - 1. \quad (19)$$

The probability $P(F)$ of this event is $3.541 \cdot 10^{-4}$, obtained by standard MCS with $N_T = 500000$ samples drawn.

5.2 Application

In this Section, the SS and LS methods are applied for i) the estimation of the functional failure probability $P(F)$ (Section 5.2.1) and ii) the sensitivity analysis of the performance of the 600-MW GFR passive decay heat removal system in Figure 4 (Section 5.2.2).

5.2.1 Functional failure probability estimation

For completeness and only for illustration purposes, Table 6 reports the values of the estimates $\hat{P}(F)$ of the functional failure probability $P(F)$ obtained by SS with $N_T = 1850$ samples (i.e., $m = 4$ simulation levels, each with $N = 500$ samples) and LS with $N_T = 1850$; for comparison purposes, the results obtained by standard MCS with the same number $N_T = 1850$ of samples are also presented. In order to evaluate the *accuracy* of the SS and LS estimates, a “true” value of the functional failure probability $P(F)$ is also reported in Table 6 for reference (i.e., $P(F) = 3.541 \cdot 10^{-4}$); this has been obtained by standard MCS with a very large number N_T (i.e., $N_T = 500000$) of simulations of the original T-H code, which actually runs fast enough to allow repetitive calculations (one code run lasts on average 3 seconds on a Pentium 4 CPU 3.00GHz). Finally, in order to evaluate the *precision* of the SS and LS estimates, the standard deviation $\hat{\sigma}[\hat{P}(F)]$ of $\hat{P}(F)$ is also computed.

Table 6

As before, LS significantly outperforms the other methods in terms of *accuracy* (i.e., the LS failure probability estimate $\hat{P}(F)$ is *closer* to the true value $P(F)$ than those of the other methods) and *precision* (i.e., the standard deviation $\hat{\sigma}[\hat{P}(F)]$ of $\hat{P}(F)$ is *lower* than those of the other methods) of the failure probability estimates.

5.2.2 Sensitivity analysis results

The *same* $N_T = 1850$ samples used in the previous Section 5.2.1 to estimate the functional failure probability of the nuclear passive system are here used to analyze the sensitivity of its performance to the uncertain input variables $\{x_j; j = 1, 2, \dots, 9\}$ of Table 5. In particular, in Section 5.2.2.1, the results obtained by the SS- and LS-based *local* reliability sensitivity approaches of Sections 3.1.2.1 and 3.2.2, respectively, are shown. In Section 5.2.2.2, the results obtained by the SS-based *global* approach of Section 3.1.2.2 are presented; in addition, the sensitivity insights provided by the SS-based method are compared to those produced by Sobol indices.

5.2.2.1 Local reliability sensitivity results

Table 7 reports the values of the estimates $\partial\hat{P}(F)/\partial\mu_{\theta_j}$ and $\partial\hat{P}(F)/\partial\sigma_{\theta_j}$ of the partial derivatives $\partial P(F)/\partial\mu_{\theta_j}$ and $\partial P(F)/\partial\sigma_{\theta_j}$ of the functional failure probability $P(F)$ with respect to the mean μ_{θ_j} and the standard deviation σ_{θ_j} of the distributions of the uncertain input parameters $\{\theta_j: j = 1, 2, \dots, 9\}$, computed by standard MCS, SS and LS with $N_T = 1850$ samples. “True” values of $\partial P(F)/\partial\mu_{\theta_j}$ and $\partial P(F)/\partial\sigma_{\theta_j}$ is also reported in Table 7 for reference: as before, these have been obtained by standard MCS with a very large number N_T (i.e., $N_T = 500000$) of simulations of the original T-H code. The ranking of the uncertain input parameters $\{\theta_j: j = 1, 2, \dots, 9\}$ based on the estimates $\partial\hat{P}(F)/\partial\mu_{\theta_j}$ and $\partial\hat{P}(F)/\partial\sigma_{\theta_j}$ is shown in parentheses⁵.

Table 7

It can be seen that:

- a ranking of the importance of the uncertain input variables $\{\theta_j: j = 1, 2, \dots, 9\}$ in affecting the functional failure probability of the passive system can be established on the basis of the *magnitude* of the absolute values of the estimates $\partial\hat{P}(F)/\partial\mu_{\theta_j}$ and $\partial\hat{P}(F)/\partial\sigma_{\theta_j}$, $j = 1, 2, \dots, 9$: obviously, the larger the absolute values of $\partial\hat{P}(F)/\partial\mu_{\theta_j}$ and $\partial\hat{P}(F)/\partial\sigma_{\theta_j}$, the stronger the impact of the corresponding uncertain variable on the functional failure probability of the system. For example, referring to the results obtained by standard MCS with $N_T = 500000$ samples, the absolute values of $\partial\hat{P}(F)/\partial\mu_{\theta_j}$ and $\partial\hat{P}(F)/\partial\sigma_{\theta_j}$ are 1.0706 and 1.0427, respectively, for variable θ_8 (i.e., the friction factor in mixed convection) and 0.1576 and 0.0257, respectively, for variable θ_1 (i.e., the reactor power): thus, θ_8 is much more important than θ_1 in affecting the functional failure probability of the passive system;
- the *sign* of the estimates $\partial\hat{P}(F)/\partial\mu_{\theta_j}$, $j = 1, 2, \dots, 9$, indicates the *direction* towards which the corresponding uncertain inputs have to move in order to drive the system to failure: for instance, since the sign of $\partial\hat{P}(F)/\partial\mu_{\theta_2}$ and $\partial\hat{P}(F)/\partial\mu_{\theta_5}$ is *negative*, the failure probability

⁵ As before, since the results produced by LS are obtained in the standard normal space by construction (see Sections 3.2.1 and 3.2.2 for details), for comparison with the other methods, the uncertain input variables $\{x_j: j = 1, 2, \dots, 9\}$ of Table 5 have been transformed into $\{\theta_j: j = 1, 2, \dots, 9\}$ in the standard normal space and the system performance indicator $Y(\mathbf{x})$ (27) (together with the corresponding LSF $g_x(\mathbf{x})$ (29)) has been transformed into $Y(\boldsymbol{\theta})$ (and, correspondingly, $g_{\boldsymbol{\theta}}(\boldsymbol{\theta})$) in the standard normal space: thus, the partial derivatives of the system failure probability with respect to the parameters of the distributions of the uncertain input variables are estimated in the standard normal space for *all* the simulation methods considered.

$P(F)$ of the passive system will be increased (resp., decreased) by decreasing (resp., increasing) the value of the means μ_{θ_2} and μ_{θ_5} of parameters θ_2 (i.e., pressure) and θ_5 (i.e., Nusselt number in mixed convection), respectively; in other words, the passive system will be effectively driven to failure by *decreasing* the value of parameters θ_2 and θ_5 , i.e., by moving them towards *low* values. On the contrary, since the sign of $\partial \hat{P}(F)/\partial \mu_{\theta_8}$ is *positive*, the failure probability $P(F)$ of the passive system will be increased (resp., decreased) by increasing (resp., decreasing) the value of the mean μ_{θ_8} of parameter θ_8 (i.e., friction factor in mixed convection); in other words, failure of the passive system will be easily caused by *increasing* the value of parameter θ_8 , i.e., by moving it towards *high* values. It is worth noting that these results are quite reasonable from a *physical* viewpoint. In fact, the pressure of the system strongly affects the density of the coolant helium gas and thus the extent of the buoyancy force on which the effective functioning of the natural circulation system is based. In particular, a decrease in the system pressure leads to a decrease in the buoyancy force which may not succeed in balancing the pressure losses around the natural circulation loop. Nusselt numbers instead are directly (i.e., linearly) related to the heat transfer coefficients in both the heater (i.e., the core, item 4 in Figure 4) and the cooler (i.e., the heat exchanger, item 12 in Figure 4) and thus their variations directly impact the global heat removal capacity of the passive system. In particular, a decrease in the heat transfer coefficient in the heat exchanger (where the wall temperature is imposed) leads to a reduction in the heat flux and consequently to an increase in the coolant temperature. Further, a decrease in the heat transfer coefficient in the heater (where the heat flux is imposed as constant) causes an increase in the coolant wall temperature. Thus, both processes lead to a rapid attainment of the coolant temperature limits. Finally, the friction factors directly determine the extent of the pressure losses which oppose the coolant flow in natural circulation. In particular, an increase in the friction factors determines an increase in the pressure losses along the closed loop and consequently a reduction in the coolant flow rate. The smaller the flow rate in the decay heat removal loop, the higher the coolant temperature rise will be, leading to an earlier attainment of the coolant temperature limits, thus worsening the safety of the operation and of the reactor;

- the information provided by $\partial \hat{P}(F)/\partial \sigma_{\theta_j}$, $j = 1, 2, \dots, 9$, is useful in identifying the variables whose uncertainty (quantified in this case by the standard deviation σ_{θ_j} of the corresponding probability distribution) plays a major role in affecting $P(F)$: based on this information, the analyst may focus his/her efforts on increasing the state-of-knowledge only

on these variables and the related physical phenomena (for example, by the collection of experimental data one may achieve an improvement in the state-of-knowledge on the correlations used to model the heat transfer process in mixed convection: this could lead to a reduction in the uncertainty, e.g., of variable θ_5 , i.e., the Nusselt number in mixed convection);

- LS with $N_T = 1850$ samples produces the same ranking of the uncertain variables as the reference one (i.e., the one produced by standard MCS with $N_T = 500000$ samples): however, this result is obtained at a much lower (i.e., by a factor 270) computational effort;
- SS with $N_T = 1850$ correctly ranks the first five uncertain variables, i.e., θ_2 , θ_8 , θ_3 , θ_5 and θ_1 , whereas standard MCS with the same number of samples is not even able to produce a ranking (in fact, $\partial \hat{P}(F)/\partial \mu_{\theta_j} = \partial \hat{P}(F)/\partial \sigma_{\theta_j} = 0$ for $j = 1, 2, \dots, 9$). This is explained as follows: in the SS procedure (due to successive conditional MCMC simulations) a large number of samples is generated in the intermediate conditional regions and in the failure region of interest, which are used to calculate $\partial \hat{P}(F)/\partial \mu_{\theta_j}$ and $\partial \hat{P}(F)/\partial \sigma_{\theta_j}$, $j = 1, 2, \dots, 9$, according to (8) and (9); instead, in standard MCS with $N_T = 1850$ samples, on average only $N_T \cdot P(F) = 1850 \cdot 3.541 \cdot 10^{-4} \approx 0.6$ (i.e., in practice *zero*) failure samples are generated which can be used to calculate $\partial \hat{P}(F)/\partial \mu_{\theta_j}$ and $\partial \hat{P}(F)/\partial \sigma_{\theta_j}$, $j = 1, 2, \dots, 9$, using an estimator similar to (8).

A final remark is in order with respect to the effectiveness of the SS- and LS-based local approaches to sensitivity analysis. They present the advantage over other standard techniques of sensitivity analysis of being directly “embedded” in the computation of the functional failure probability: in fact, the SS and LS algorithms produce the “ingredients” used for sensitivity analysis (i.e., the empirical conditional distributions in SS and the random lines parallel to the important vector α in LS) *during the simulation* that is performed to compute the functional failure probability of the passive system. In other words, *while* estimating the functional failure probability of the system, sensitivity analysis results are produced that can be readily visualized for identification and ranking of the most important variables. This is of particular interest in practical cases in which the computer codes require several hours (or even days) to run a single simulation.

5.2.2.2 Global sensitivity results

The results obtained in the previous Section 5.2.2.1 by the local reliability sensitivity approaches are compared here to those produced by the SS-based global approach of Section 3.1.2.2.

The sensitivity of the passive system performance to the individual uncertain input parameters of Table 5 is studied by examining the change of the sample distributions at different conditional levels. The histograms of the conditional samples of five uncertain parameters (i.e., x_1 , the reactor power; x_2 , the pressure level established in the guard containment after the LOCA; x_3 , the cooler wall temperature; x_5 , the Nusselt number in mixed convection; x_8 , the friction factor in mixed convection) at different conditional levels for a *single* SS run are shown in Figure 5, left. It can be seen that the performance of the passive system is strongly sensitive to the pressure level established in the guard containment after the LOCA, as indicated by the significant leftward shift of its empirical conditional distribution (histograms) from the unconditional one (solid lines). A sensitivity of the passive system performance is also *visually* observed with respect, e.g., to the cooler wall temperature (rightward shift) and to the correlation errors in both the Nusselt number (leftward shift) and the friction factor (rightward shift) in mixed convection.

The “pictorial” information contained in the empirical conditional distributions $q(x_j|F_i)$, $j = 1, 2, \dots, n_i$, $i = 1, 2, \dots, m$, is used as before to *refine* the sensitivity information by obtaining the distribution of the system failure probability conditional on the values of the individual uncertain input parameters, i.e. $P(F|x_j)$, according to (10) (Figure 5, right): for example, it can be seen that fixing x_2 to 1500 kPa would result in $P(F) = 0$, whereas fixing x_2 to 1200 kPa would result in $P(F) \approx 0.40$.

Figure 5

The results shown in Figure 5, right, are used to rank the uncertain input variables $\{x_j; j = 1, 2, \dots, 9\}$ according to their effectiveness in driving the passive system to failure (or, in other words, to quantify the importance of the variability of the individual uncertain input variables in determining the failure probability of the system). As before, a ranking is established on the basis of the maximum value assumed by the distributions $P(F|x_j)$, $j = 1, 2, \dots, 9$. For example, as x_2 varies in its range, $P(F|x_2)$ takes values from 0 to 0.45, whereas as x_8 varies in its range, $P(F|x_8)$ takes values from 0 to 0.012: thus, it can be concluded that x_2 is *much* more important than x_8 in affecting the functional failure probability of the passive system (or, in other words, in driving the system to failure). According to this criterion the uncertain input variables $\{x_j; j = 1, 2, \dots, 9\}$ are ranked fifth, first, third, ninth, fourth, sixth, eighth, second and seventh, respectively; note that this ranking is in satisfactory agreement with those provided by the SS- and LS-based local reliability sensitivity approaches (see Table 7 of Section 5.2.2.1).

In addition, it is worth noting again that the global sensitivity analysis based on SS presents the advantage over the standard sensitivity analysis techniques (e.g., variance-based methods like Sobol

indices), of being directly “embedded” in the computation of the failure probability: the SS algorithm produces the empirical conditional distributions of Figure 5 *during the simulation* that is performed to compute the functional failure probability of the passive system.

Finally, for completeness the sensitivity insights provided by the SS-based global approach are also compared to those produced by (global) Sobol indices [45]: in particular, for brevity only the total-order Sobol indices $S_{Tj}^{y_1}$, $S_{Tj}^{y_2}$ and S_{Tj}^Y , $j = 1, 2, \dots, 9$, are calculated for the outputs of the T-H code, i.e., $y_1(\mathbf{x}) = T_{out,core}^{hot}(\mathbf{x})$ and $y_2(\mathbf{x}) = T_{out,core}^{avg}(\mathbf{x})$, and for the performance function $Y(\mathbf{x})$ (27) of the passive system, respectively. Table 8 reports the values of $S_{Tj}^{y_1}$, $S_{Tj}^{y_2}$ and S_{Tj}^Y , $j = 1, 2, \dots, 9$, obtained using the algorithm proposed by [44] with $N_T = 550000$ runs of the T-H model code. The ranking of the uncertain parameters is also shown in parentheses.

Table 8

It can be seen that:

- not surprisingly, different indices provide different rankings: for example, variables x_3 , x_5 and x_8 are ranked fourth, third and second, respectively, by both $S_{Tj}^{y_1}$ and S_{Tj}^Y , whereas they are ranked third, second and fourth, respectively, by $S_{Tj}^{y_2}$;
- the ranking provided by $S_{Tj}^{y_1}$ is the same as that produced by S_{Tj}^Y : this leads to conclude that the hot channel coolant outlet temperature $T_{out,core}^{hot}(\mathbf{x}) = y_1(\mathbf{x})$ is “dominant” over the average channel coolant outlet temperature $T_{out,core}^{avg}(\mathbf{x}) = y_2(\mathbf{x})$ in determining the uncertain behavior of the passive system performance function $Y(\mathbf{x})$ (27);
- the ranking provided by S_{Tj}^Y is similar to that produced by the SS-based global approach (see Figure 5): for example, variables x_1 , x_2 , x_7 and x_8 are ranked fifth, first, eighth and second, respectively, by both approaches. However, a difference is found in the ranking of variables x_3 and x_5 : in particular, variable x_3 is ranked fourth and third by the Sobol- and SS-based approaches, respectively; conversely, variable x_5 is ranked third and fourth by the Sobol- and SS-based approaches, respectively. This confirms that in general, the most important contributors to the variability of model output(s) do not necessarily coincide with the most important contributors to system failure.

6 Conclusions

The assessment of the functional failure probability of T-H passive systems can be performed by sampling the uncertainties in the system model and parameters, and simulating the corresponding passive system response with T-H computer codes. Within this framework, sensitivity analysis has two objectives: i) the quantification of the importance of the individual uncertain parameters in affecting the performance of the passive system (or, in other words, in determining the functional failure probability of the passive system); ii) the determination of the contribution of the individual uncertain parameters (i.e., the inputs to the T-H code) to the uncertainty in the outputs of the T-H code. However, since sensitivity analysis relies on *multiple* evaluations of the T-H code for different combinations of system inputs, the associated computational effort may be prohibitive due to the long-running times of the T-H codes.

Thus, in this paper the advanced SS and LS methods have been considered for performing an efficient sensitivity analysis of the performance of a T-H passive system *while* estimating its functional failure probability by means of a reasonably *limited* number of T-H code evaluations.

Different local and global approaches to sensitivity analysis have been considered and compared with reference to two case studies of literature: the first one involving the Ishigami function [1]; the second one considering the natural convection cooling in a Gas-cooled Fast Reactor (GFR) after a Loss of Coolant Accident (LOCA) [2]. On the basis of the results obtained, the following guidelines and recommendations can be drawn:

- with reference to objective i) above, two options are suggested:
 1. in those cases where the analyst is able to get information about the “structure” of the failure region (e.g., one/multiple overlapping/disconnected failure regions, ...), the concept of local reliability sensitivity analysis based on LS can be embraced (Section 3.2.2). Actually, as demonstrated by Case study 1, the possibility of identifying multiple important directions allows to *separate* the contributions of (possibly) multiple failure regions to the reliability sensitivity indices (i.e., the partial derivatives of the system failure probability with respect to the moments of the distributions of the uncertain input parameters): this avoids *averaging* or (even worse) *canceling* the different contributions, which would provide erroneous and misleading indications. In addition, as demonstrated by Case studies 1 and 2, LS provides much more accurate and precise failure probability estimates than the other simulation methods here considered for comparison (i.e., standard MCS and SS): this allows the analyst to reduce the number of samples (and, thus, of T-H model evaluations) necessary to

obtain desired estimation accuracies and precisions (in particular, in those practical cases where the computer codes require several hours to run a single simulation).

2. in those (more realistic) cases where the analyst has no information about the “structure” of the failure region (or, alternatively, information can be obtained at impractical computational costs), the global approach based on SS may represent the optimal choice (Section 3.1.2.2): indeed, as demonstrated by Case study 1, SS is able to automatically identify multiple disconnected failure regions without any input from the analyst. In particular, SS generates a *large* amount of conditional samples by searching the *whole* uncertain input space by means of *sequential* Markov Chain Monte Carlo (MCMC) simulations; by so doing, the *entire distribution* of the system failure probability conditional on the values of the individual uncertain input parameters is produced: the associated information is relevant from the sensitivity analysis viewpoint because it quantifies how the failure probability of the system would change if a given uncertain input parameter were set to a given value (e.g., if its epistemic uncertainty were reduced).

A final remark is in order with respect to the effectiveness of the SS- and LS-based approaches to sensitivity analysis. They present the advantage over other standard techniques of sensitivity analysis of being directly “embedded” in the computation of the system failure probability: the SS and LS algorithms produce the “ingredients” used in sensitivity analyses (i.e., the empirical conditional distributions in SS and the random lines parallel to the important vector in LS) *during the simulation* that is performed to compute the system failure probability. In other words, *while* estimating the failure probability of the system, sensitivity analysis results are produced that can be readily visualized for identification and ranking of the most important variables. This is of particular interest in practical cases in which the computer codes require several hours (or even days) to run a single simulation (like in the present case of passive system reliability assessment).

- with reference to objective ii) above, the use of “classical” variance-based techniques (e.g., those relying on the computation of first- and total-order Sobol indices, like in the present paper) is suggested: actually, by construction these methods quantify the proportion of the variance of the system model outputs that can be attributed to the variance of the uncertain input variables.

However, two issues must be taken into account for the practical use of these techniques in passive system reliability assessments:

1. the associated computational burden may be prohibitive because thousands or millions of system model evaluations are frequently required for the computation of variance-based (Sobol) indices through Monte Carlo-based techniques; in addition, these techniques cannot be embedded in the estimation of the failure probability of the passive system: thus, the T-H model evaluations necessary for performing the sensitivity analysis have to be *added* to those carried out for estimating the failure probability, further increasing the computational burden. To overcome this issue, the adoption of fast-running meta-models in substitution of the original (typically long-running) system model codes is strongly advised;
2. care should be taken in the interpretation of the uncertain variable ranking provided by these methods: as demonstrated by Case study 1, the most important contributors to the *variability* (in practice, the *variance*) of the system *model outputs* are *not necessarily* the most important contributors to *system failure* (i.e., those parameters that influence most the passive system *failure probability*).

References

- [1] Homma, T. and Saltelli, A., 1996. Importance measures in global sensitivity analysis of model output. *Reliability Engineering and System Safety*, 52, pp. 1-17.
- [2] Pagani, L., Apostolakis, G.E. and Hejzlar, P., 2005. The impact of uncertainties on the performance of passive systems. *Nuclear Technology*, 149, 129-140.
- [3] IAEA, 1991. Safety related terms for advanced nuclear plant. IAEA TECDOC-626.
- [4] Nayak, A. K., Gartia, M. R., Antony, A., Vinod, G., Sinha, R. K., 2008. Passive system reliability analysis using the APSRA methodology. *Nuclear Engineering and Design*, 238, pp. 1430-1440.
- [5] Nayak, A. K., Jain, V., Gartia, M. R., Srivastava, A., Prasad, H., Anthony, A., Gaikwad, A. J., Bhatia, S. K., Sinha, R. K., 2008. Reliability assessment of passive isolation condenser system using APSRA methodology. *Annals of Nuclear Energy*, 35, pp. 2270-2279.
- [6] Nayak, A. K., Jain, V., Gartia, M. R., Prasad, H., Anthony, A., Bhatia, S. K., Sinha, R. K., 2009. Reliability assessment of passive isolation condenser system of AHWR using APSRA methodology. *Reliability Engineering and System Safety*, 94, pp. 1064-1075.
- [7] Apostolakis, G. E., 1990. The concept of probability in safety assessment of technological systems. *Science*, 250, 1359.
- [8] Helton, J., Oberkampf, W., 2004. Alternative representations of epistemic uncertainties. *Reliability Engineering and System Safety*, 85 (Special Issue).
- [9] Burgazzi, L., 2002. Passive system reliability analysis: a study on the isolation condenser. *Nuclear Technology*, 139 (July), 3-9.
- [10] Burgazzi, L., 2003. Reliability evaluation of passive systems through functional reliability assessment. *Nuclear Technology*, 144, 145.
- [11] Burgazzi, L., 2004. Evaluation of uncertainties related to passive systems performance. *Nuclear Engineering and Design*, 230, 93-106.
- [12] Burgazzi, L., 2006. Failure mode and effect analysis application for the safety and reliability analysis of a thermal-hydraulic passive system. *Nuclear Technology*, 146, pp. 150-158.
- [13] Burgazzi, L., 2007. Addressing the uncertainties related to passive system reliability. *Progress in Nuclear Energy*, 49, 93-102.
- [14] Burgazzi, L., 2007. State of the art in reliability of thermal-hydraulic passive systems. *Reliability Engineering and System Safety*, 92, pp. 671-675.
- [15] Burgazzi, L., 2007. Thermal-hydraulic passive system reliability-based design approach. *Reliability Engineering and System Safety*, 92(9), pp. 1250-1257.
- [16] Burgazzi, L., 2008. About time-variant reliability analysis with reference to passive systems assessment. *Reliability Engineering and System Safety*, 93(11), pp. 1682-1688.
- [17] Burgazzi, L., 2009. Evaluation of the dependencies related to passive system failure. *Nuclear Engineering and Design*, 239(12), pp. 3048-3053.
- [18] Woo, TH, Lee, UC, 2009. Dynamical reliability of the passive system in the very high temperature gas cooled reactor. *Annals of Nuclear Energy*, 36: 1299-1306.
- [19] Woo, TH, Lee, UC, 2009. Passive system reliability in the nuclear power plants (NPPs) using statistical modeling. *Nuclear Engineering and Design*, 239(12): 3014-3020.
- [20] Woo, TH, Lee, UC, 2010. The statistical analysis of the passive system reliability in the Nuclear Power Plants (NPPs). *Progress in Nuclear Energy*, 52: 456-461.
- [21] Han, SJ, Yang, JE, 2010. A quantitative evaluation of reliability of passive systems within probabilistic safety assessment framework for VHTR. *Annals of Nuclear Energy*, 37: 345-358.
- [22] Jafari, J., D' Auria, F., Kazeminejad, H., Davilu, H., 2003. Reliability evaluation of a natural circulation system. *Nuclear Engineering and Design*, 224, 79-104.
- [23] Zio, E., Cantarella, M., Cammi, A., 2003. The analytic hierarchy process as a systematic approach to the identification of important parameters for the reliability assessment of passive systems. *Nuclear Engineering and Design*, 226, 311-336.

- [24] Marquès, M., Pignatell, J. F., Saignes, P., D' Auria, F., Burgazzi, L., Müller, C., Bolado-Lavin, R., Kirchsteiger, C., La Lumia, V., Ivanov, I., 2005. Methodology for the reliability evaluation of a passive system and its integration into a probabilistic safety assessment. *Nuclear Engineering and Design*, 235, 2612-2631.
- [25] Bassi, C., Marquès, M., 2008. Reliability assessment of 2400 MWth gas-cooled fast reactor natural circulation decay heat removal in pressurized situations. *Science and Technology of Nuclear Installations*, Special Issue "Natural Circulation in Nuclear Reactor Systems", Hindawi Publishing Corporation, Paper 87376.
- [26] Mackay F. J., Apostolakis, G. E., Hejzlar, P., 2008. Incorporating reliability analysis into the design of passive cooling systems with an application to a gas-cooled reactor. *Nuclear Engineering and Design*, 238(1), pp. 217-228.
- [27] Mathews, T. S., Ramakrishnan, M., Parthasarathy, U., John Arul, A., Senthil Kumar, C., 2008. Functional reliability analysis of safety grade decay heat removal system of Indian 500 MWe PFBR. *Nuclear Engineering and Design*, 238(9), pp. 2369-2376.
- [28] Mathews, T.S., Arul, A.J., Parthasarathy, U., Kumar, C.S., Ramakrishnan, M., Subbaiah, K.V., 2009. Integration of functional reliability analysis with hardware reliability: An application to safety grade decay heat removal system of Indian 500 MWe PFBR. *Annals of Nuclear Energy*, 36, pp. 481-492.
- [29] Patalano, G., Apostolakis, G. E., Hejzlar, P., 2008. Risk-informed design changes in a passive decay heat removal system. *Nuclear Technology*, vol. 163, pp. 191-208.
- [30] Arul, A.J., Iyer, N.K., Velusamy, K., 2009. Adjoint operator approach to functional reliability analysis of passive fluid dynamical systems. *Reliability Engineering and System Safety*, 94, pp. 1917-1926.
- [31] Arul, A.J., Kannan Iyer, N., Velusamy, K., 2010. Efficient reliability estimate of passive thermal hydraulic safety system with automatic differentiation. *Nuclear Engineering and Design*, doi:10.1016/j.nucengdes.2010.05.012.
- [32] Fong, C. J., Apostolakis, G. E., Langewish, D. R., Hejzlar, P., Todreas, N. E., Driscoll, M. J., 2009. Reliability analysis of a passive cooling system using a response surface with an application to the flexible conversion ratio reactor. *Nuclear Engineering and Design*, 239(12), pp. 2660-2671.
- [33] Zio, E., Pedroni, N., 2009. Building confidence in the reliability assessment of thermal-hydraulic passive systems. *Reliability Engineering and System Safety*, vol. 94(2), pp. 268-281.
- [34] Zio, E. and Pedroni, N., 2009. Estimation of the functional failure probability of a thermal-hydraulic passive systems by means of Subset Simulation. *Nuclear Engineering and Design*, 239, pp. 580-599.
- [35] Zio, E. and Pedroni, N., 2009. Functional failure analysis of a thermal-hydraulic passive system by means of Line Sampling. *Reliability Engineering and System Safety*, 94(11), pp. 1764-1781.
- [36] Zio, E., Pedroni, N., 2010. An optimized Line Sampling method for the estimation of the failure probability of nuclear passive systems. *Reliability Engineering and System Safety*, doi:10.1016/j.ress.2010.06.007.
- [37] Pedroni, N., Zio, E., Apostolakis, G. E., 2010. Comparison of bootstrapped Artificial Neural Networks and quadratic Response Surfaces for the estimation of the functional failure probability of a thermal-hydraulic passive system. *Reliability Engineering and System Safety*, 95(4): 386-395.
- [38] Zio, E., Apostolakis, G. E., Pedroni, N., 2010. Quantitative functional failure analysis of a thermal-hydraulic passive system by means of bootstrapped Artificial Neural Networks. *Annals of Nuclear Energy*, 37(5): 639-649.
- [39] Saltelli, A., Ratto, M., Andres, T., Campolongo, F., Cariboni, J., Gatelli, D., Saisana, M., Tarantola, S., 2008. *Global sensitivity analysis. The Primer*. John Wiley and Sons Ltd.

- [40] Volkova, E., Iooss, B., Van Dorpe, F., 2008. Global sensitivity analysis for a numerical model of radionuclide migration from the RRC “Kurchatov Institute” redwaste disposal site. *Stoch Environ Res Assess*, 22: pp. 17-31.
- [41] Marrel, A., Iooss, B., Laurent, B., Roustant, O., 2009. Calculations of Sobol indices for the Gaussian process metamodel. *Reliability Engineering and System Safety*, vol., 94, pp. 742-751.
- [42] Saltelli, A., Ratto M., Tarantola, S., Campolongo, F., 2005. Sensitivity analysis for chemical models. *Chemical Reviews*, 105(7), pp. 2811–28.
- [43] Borgonovo, E., 2007. A new uncertainty importance measure. *Reliability Engineering and System Safety*, 92, pp. 771-784.
- [44] Saltelli, A., 2002. Making best use of model evaluations to compute sensitivity indices. *Comput. Phys. Commun.*, vol. 145, pp. 280-297.
- [45] Sobol, I. M., 1993. Sensitivity analysis for nonlinear mathematical model. *Math. Modelling Comput. Exp.*, 1, pp. 407-414.
- [46] Saltelli, A., 2002. Sensitivity analysis for importance assessment. *Risk Analysis*, 22(3), pp. 579-590.
- [47] Saltelli, A., Tarantola, S., Chan, K.P.S., 1999. A quantitative model-independent for global sensitivity analysis of model output. *Technometrics*, 41(1), pp. 39-56.
- [48] Chun M-H, Han S-J, Tak N-IL. An uncertainty importance measure using a distance metric for the change in a cumulative distribution function. *Reliab Eng Syst Saf*, 70, pp. 313–321.
- [49] Borgonovo, E., 2006. Measuring Uncertainty Importance: Investigation and Comparison of Alternative Approaches. *Risk Analysis*, 26(5), pp. 1349-1361.
- [50] Borgonovo, E. and Tarantola, S., 2008. Moment independent and variance-based sensitivity analysis with correlations: An application to the stability of a chemical reactor. *International Journal of Chemical Kinetics*, 40(11), pp. 687-698.
- [51] Liu, Q. and Homma, T., 2009. A new computational method of a moment-independent uncertainty importance measure. *Reliability Engineering and System Safety*, 94(7), pp. 1205-1211.
- [52] Borgonovo E., W. Castaings and S. Tarantola, 2011. Moment Independent Importance Measures: New Results and Analytical Test Cases. *Risk Analysis*, 31 (3), pp. 404-428.
- [53] Saltelli, A. Chan, K., Scott, M. editors, 2000. Sensitivity analysis. Probability and statistics series. New York: Wiley.
- [54] Saltelli, A., Tarantola, S., Campolongo, F., Ratto, M., 2004. Sensitivity analysis in practice. In: A guide to assessing scientific models. New York: Wiley.
- [55] Cacuci, D. G., Ionescu-Bujor, M., 2004. A comparative review of sensitivity and uncertainty analysis of large scale systems – II: Statistical methods. *Nuclear Science and Engineering* (147), pp. 204-217.
- [56] Helton, J.C., Davis, F.J., Johnson, J.D., 2005. A Comparison of Uncertainty and Sensitivity Analysis Results Obtained with Random and Latin Hypercube Sampling. *Reliability Engineering & System Safety*, Vol. 89, 3, pp. 305-330.
- [57] Helton J. C, Johnson J. D., Sallaberry C. J., Storlie C. B., 2006. Survey on sampling-based methods for uncertainty and sensitivity analysis. *Reliability Engineering and System Safety*, 91, pp. 1175-1209.
- [58] Campolongo, F., Cariboni, J., Saltelli, A., 2007. Simplifying a large chemical reaction model via an effective screening design. *Environmental Modelling & Software*, 22, pp. 1509–18.
- [59] Pourgol-Mohamad, M., Mosleh, A., Modarres, M., 2009. Methodology for the use of experimental data to enhance model output uncertainty assessment in thermal hydraulics codes. *Reliability Engineering and System Safety*, Volume 95(2), pp. 77-86.
- [60] Au, S. K. and Beck, J. L., 2001. Estimation of small failure probabilities in high dimensions by subset simulation. *Probabilistic Engineering Mechanics*, 16(4), pp. 263-277.

- [61] Au, S. K. and Beck, J. L., 2003. Subset Simulation and its application to seismic risk based on dynamic analysis. *Journal of Engineering Mechanics*, 129(8), pp. 1-17.
- [62] Koutsourelakis, P. S., Pradlwarter, H. J., Schueller, 2004. Reliability of structures in high dimensions, Part I: algorithms and application. *Probabilistic Engineering Mechanics* (19), pp. 409-417.
- [63] Pradlwarter, H. J., Pellissetti, M. F., Schenk, C. A., Schueller, G. I., Kreis, A., Fransen, S., Calvi, A., Klein, M., 2005. Realistic and efficient reliability estimation for aerospace structures. *Computer Methods in Applied Mechanics and Engineering*, 194, pp. 1597-1617.
- [64] Metropolis, N., Rosenbluth, A. W., Rosenbluth, M. N. and Taller, A. H., 1953. Equations of state calculations by fast computing machines. *Journal of Chemical Physics*, 21(6), pp. 1087-1092.
- [65] Song, S., Lu, Z., Qiao, H., 2009. Subset simulation for structural reliability sensitivity analysis. *Reliability Engineering and System Safety*, 94, pp. 658-665.
- [66] Au, S. K., 2005. Reliability-based design sensitivity by efficient simulation. *Computers and Structures*, 83, pp. 1048-1061.
- [67] Au, S. K., Wang, Z. H., Lo, S. M., 2007. Compartment fire risk analysis by advanced Monte Carlo simulation. *Engineering Structures*, 29(9), pp. 2381-2390.
- [68] Song, S.F., Lu Z.Z., 2007. Improved line sampling method for structural reliability with high dimensionality and small failure probability. *Acta Aeronautica et Astronautica Sinica*, 28(3): pp. 596-599 [in Chinese].
- [69] Song, S.F., Lu Z.Z., 2007. Improved line sampling reliability analysis method and its application. *Key Engineering Materials*, 353-358: pp. 1001-1004.
- [70] Lu, Z., Song, S., Yue, Z., Wang, J., 2008. Reliability sensitivity method by Line Sampling. *Structural Safety*, vol. 30, pp. 517-532.
- [71] Song, S., Lu, Z., Zhang, W., Ye, Z., 2009. Reliability and Sensitivity Analysis of Transonic Flutter Using Improved Line Sampling Technique. *Chinese Journal of Aeronautics*, 22, pp. 513-519.
- [72] Ching, J., Beck, J. L., Au, S. K., 2005. Hybrid subset simulation method for reliability estimation of dynamical systems subject to stochastic excitation. *Probabilistic Engineering Mechanics*, 20, pp. 199-214.
- [73] Katafygiotis, L., Cheung, S. H., 2005. A two-stage subset simulation-based approach for calculating the reliability of inelastic structural systems subjected to Gaussian random excitations. *Computer Methods in Applied Mechanics and Engineering*, 194, pp. 1581-1595.
- [74] Katafygiotis, L., Cheung, S. H., 2007. Application of spherical subset simulation method and auxiliary domain method on a benchmark reliability study. *Structural Safety*, 29, pp. 194-207.
- [75] Au, S. K., 2007. Augmented approximate solutions for consistent reliability analysis. *Probabilistic Engineering Mechanics*, 22, pp. 77-87.
- [76] Pradlwarter, H. J., Schueller, G. I., Koutsourelakis, P. S., Charmpis, D. C., 2007. Application of line sampling simulation method to reliability benchmark problems. *Structural Safety*, 29, pp. 208-221.
- [77] Liu, H. and Chen, W., 2004. Probabilistic sensitivity analysis methods for design under uncertainty. In: 10th AIAA/ISSMO multidisciplinary analysis and optimization conference, New York, 2004.
- [78] Ahammed M., Melchers, R.E., 2006. Gradient and parameter sensitivity estimation for systems evaluated using Monte Carlo analysis. *Reliability Engineering and System Safety*, 91, pp. 594-601.
- [79] Wu, Y.T., Mohanti, S., 2006. Variable screening and ranking using sampling-based sensitivity measures. *Reliability Engineering and System Safety*, 91, pp. 634-47.
- [80] Schueller, G. I., Pradlwarter, H. J., Koutsourelakis, P. S., 2004. A critical appraisal of reliability estimation procedures for high dimensions. *Probabilistic Engineering Mechanics*, 19, pp. 463-474.

- [81] Schueller, G. I., Pradlwarter, H. J., 2007. Benchmark study on reliability estimation in higher dimensions of structural systems – An overview. *Structural Safety*, 29(3), pp. 167-182.
- [82] Schueller, G. I., 2009. Efficient Monte Carlo simulation procedures in structural uncertainty and reliability analysis - recent advances. *Journal of Structural Engineering and Mechanics*, 32(1):1–20, 2009.
- [83] Valdebenito, M. A., Pradlwarter, H. J., Schueller, G. I., 2010. The role of the design point for calculating failure probabilities in view of dimensionality and structural nonlinearities. *Structural Safety*, 32(2), pp. 101-111.
- [84] Zhao, Y.G., Ang, A.H-S., 2003. System reliability assessment by method of moments. *Struct Eng*, 129(10), pp. 1341–1349.
- [85] Storlie C.B., Swiler L.P., Helton J.C., Sallaberry C.J., 2009. Implementation and evaluation of nonparametric regression procedures for sensitivity analysis of computationally demanding models. *Reliability Engineering and System Safety* 2009; 94: 1735-1763.
- [86] NUREG-1150, 1990. Severe accident risk: an assessment for five US nuclear power plants, US Nuclear Regulatory Commission.
- [87] Helton, J. C., 1998. Uncertainty and sensitivity analysis results obtained in the 1996 performance assessment for the waste isolation power plant, SAND98-0365, Sandia National Laboratories.
- [88] USNRC, 2002. An approach for using probabilistic risk assessment in risk-informed decisions on plant-specific changes to the licensing basis. NUREG-1.174 – Revision 1, US Nuclear Regulatory Commission, Washington, DC.
- [89] USNRC, 2009. Guidance on the Treatment of Uncertainties Associated with PRAs in Risk-Informed Decision Making. NUREG-1855, US Nuclear Regulatory Commission, Washington, DC.
- [90] NUREG-CR-6850, 2005. EPRI/NRC-RES Fire PRA methodology for nuclear power facilities, Volume 2: detailed methodology. US Nuclear Regulatory Commission.

FIGURE CAPTION PAGE

Figure 1. Examples of possible important unit vectors α^1 (left) and α^2 (right) pointing towards the corresponding failure domains F^1 (left) and F^2 (right) in a two-dimensional uncertain parameter space: in the situation on the left, the system would be driven to failure much more effectively by an increase in Parameter 2 rather than by an increase in Parameter 1; in the situation on the right, an increase in Parameter 1 would be much more important in determining system failure than an increase in Parameter 2

Figure 2. Failure region $F = \{\mathbf{x}: g_x(\mathbf{x}) \geq 0\}$ (dark areas) associated to the LSF $g_x(\mathbf{x})$ (21) based on the Ishigami function $Y(\mathbf{x})$ (20) in the space of the uncertain input variables $\{x_j: j = 1, 2, 3\}$: F is composed by four disconnected failure regions $\{F^l: l = 1, 2, 3, 4\}$

Figure 3. Global sensitivity analysis by SS: distributions of the system failure probability conditional on the values of the individual uncertain input parameters $\{x_j: j = 1, 2, 3\}$, i.e., $P(F|x_1)$ (top, left), $P(F|x_2)$ (top, right) and $P(F|x_3)$ (bottom) for Case study 1 of Section 4.1

Figure 4. Schematic representation of one loop of the 600-MW GFR passive decay heat removal system [2]

Figure 5. Global sensitivity analysis by SS. Left: empirical conditional distributions of uncertain input parameters x_1, x_2, x_3, x_5 and x_8 at different conditional levels (histograms) compared to their unconditional distributions (solid lines); right: distribution of the system failure probability conditional on the values of the individual uncertain input parameters x_1, x_2, x_3, x_5 and x_8 , i.e., $P(F|x_1), P(F|x_2), P(F|x_3), P(F|x_5), P(F|x_8)$

TABLES

Case study 1: Ishigami function Failure probability estimation (“True” value, $P(F) = 5.566 \cdot 10^{-4}$)		
	$\hat{P}(F)$	$\hat{\sigma}[\hat{P}(F)]$
Standard MCS	0	$3.878 \cdot 10^{-4}$
SS	$5.060 \cdot 10^{-4}$	$1.647 \cdot 10^{-4}$
LS	$5.567 \cdot 10^{-4}$	$3.756 \cdot 10^{-5}$

Table 1. Values of the failure probability estimates $\hat{P}(F)$ and corresponding standard deviations $\hat{\sigma}[\hat{P}(F)]$ obtained by standard MCS, SS and LS with $N_T = 3700$ samples for Case study 1 of Section 4.1. The “true” (i.e., reference) value (i.e., $P(F) = 5.566 \cdot 10^{-4}$) obtained by standard MCS with $N_T = 500000$ samples is also reported

	Case study 1: Ishigami function							
	Local reliability sensitivity analysis							
	MCS, $N_T = 500000$ (rank)		MCS, $N_T = 3700$ (rank)		SS, $N_T = 3700$ (rank)		LS, $N_T = 3700$ (rank)	
Parameters	$\partial \hat{P}(F)/\partial \mu_{\theta_j}$	$\partial \hat{P}(F)/\partial \sigma_{\theta_j}$	$\partial \hat{P}(F)/\partial \mu_{\theta_j}$	$\partial \hat{P}(F)/\partial \sigma_{\theta_j}$	$\partial \hat{P}(F)/\partial \mu_{\theta_j}$	$\partial \hat{P}(F)/\partial \sigma_{\theta_j}$	$\partial \hat{P}(F)/\partial \mu_{\theta_j}$	$\partial \hat{P}(F)/\partial \sigma_{\theta_j}$
θ_1	0.6781 (1)	0.5301 (3)	0.5893 (3)	0.6527 (2)	0.6750 (1)	0.5375 (2)	0.5869 (1)	0.4008 (3)
θ_2	$3.0850 \cdot 10^{-3}$ (3)	0.5329 (2)	-0.7678 (2)	0.4105 (3)	-0.2543 (2)	0.5070 (3)	-0.0240 (3)	0.4026 (2)
θ_3	$-9.2199 \cdot 10^{-3}$ (2)	6.1939 (1)	-2.4670 (1)	5.0863 (1)	-0.1240 (3)	6.4965 (1)	0.0557 (2)	5.8401 (1)

Table 2. Values of the estimates $\partial \hat{P}(F)/\partial \mu_{\theta_j}$ and $\partial \hat{P}(F)/\partial \sigma_{\theta_j}$ of the partial derivatives

$\partial P(F)/\partial \mu_{\theta_j}$ and $\partial P(F)/\partial \sigma_{\theta_j}$ of the failure probability $P(F)$ with respect to the mean μ_{θ_j} and the standard deviation σ_{θ_j} of the distributions of the uncertain input parameters $\{\theta_j: j = 1, 2, 3\}$, computed in the standard normal space by standard MCS, SS and LS with $N_T = 3700$ samples for Case study 1 of Section 4.1; the ranking of the uncertain input parameters is shown in parentheses

	Case study 1: Ishigami function – Local reliability sensitivity analysis							
	Line Sampling, $N_T = 3700$ – Four important directions $\{\alpha^l: l = 1, 2, 3, 4\}$							
	α_1, F^1 (rank)		α_2, F^2 (rank)		α_3, F^3 (rank)		α_4, F^4 (rank)	
Parameters	$\partial\hat{P}(F^1)/\partial\mu_{\theta_1}$	$\partial\hat{P}(F^1)/\partial\sigma_{\theta_1}$	$\partial\hat{P}(F^2)/\partial\mu_{\theta_1}$	$\partial\hat{P}(F^2)/\partial\sigma_{\theta_1}$	$\partial\hat{P}(F^3)/\partial\mu_{\theta_1}$	$\partial\hat{P}(F^3)/\partial\sigma_{\theta_1}$	$\partial\hat{P}(F^4)/\partial\mu_{\theta_1}$	$\partial\hat{P}(F^4)/\partial\sigma_{\theta_1}$
θ_1	0.5574 (3)	0.4287 (3)	0.5343 (2)	0.4002 (2)	0.6215 (2)	0.3741 (2)	0.6382 (3)	0.3967 (3)
θ_2	0.5641 (2)	0.4391 (2)	0.5333 (3)	0.3986 (3)	-0.6205 (3)	0.3645 (3)	-0.6437 (2)	0.4035 (2)
θ_3	2.1143 (1)	6.1695 (1)	-2.0321 (1)	5.7876 (1)	2.3799 (1)	5.5034 (1)	-2.4525 (1)	5.8581 (1)

Table 3. Values of the estimates $\{\partial\hat{P}(F^l)/\partial\mu_{\theta_j} : l = 1, 2, 3, 4\}$ and $\{\partial\hat{P}(F^l)/\partial\sigma_{\theta_j} : l = 1, 2, 3, 4\}$ of the partial derivatives $\{\partial P(F^l)/\partial\mu_{\theta_j} : l = 1, 2, 3, 4\}$ and $\{\partial P(F^l)/\partial\sigma_{\theta_j} : l = 1, 2, 3, 4\}$ of the failure probability $P(F)$ with respect to the mean μ_{θ_j} and the standard deviation σ_{θ_j} of the distributions of the uncertain input parameters $\{\theta_j: j = 1, 2, 3\}$, computed in the standard normal space by LS with $N_T = 3700$ samples and four separate important directions $\{\alpha^l: l = 1, 2, 3, 4\}$ for Case study 1 of Section 4.1; the ranking of the uncertain parameters is shown in parentheses

Case study 1: Ishigami function		
Global sensitivity analysis – Sobol indices		
Parameters	S_i^g (rank)	S_{Ti}^g (rank)
x_1	0.3155 (2)	0.5596 (1)
x_2	0.4415 (1)	0.4478 (2)
x_3	0 (3)	0.2490 (3)

Table 4. First- and total-order Sobol sensitivity indices S_j^g and S_{Tj}^g , $j = 1, 2, 3$, obtained with $N_T = 500000$ model evaluations for the LSF $g_{\mathbf{x}}(\mathbf{x})$ (21) based on the Ishigami function $Y(\mathbf{x})$ (20) in Case study 1 of Section 4.1. The ranking of the uncertain input parameters is reported in parentheses

	Name	Mean, μ	Standard deviation, σ (% of μ)
Parameter uncertainty	Power (MW), x_1	18.7	1%
	Pressure (kPa), x_2	1650	7.5%
	Cooler wall temperature ($^{\circ}\text{C}$), x_3	90	5%
Model uncertainty	Nusselt number in forced convection, x_4	1	5%
	Nusselt number in mixed convection, x_5	1	15%
	Nusselt number in free convection, x_6	1	7.5%
	Friction factor in forced convection, x_7	1	1%
	Friction factor in mixed convection, x_8	1	10%
	Friction factor in free convection, x_9	1	1.5%

Table 5. Epistemic uncertainties considered for the 600-MW GFR passive decay heat removal system of Figure 4 [2]

Case study 2: nuclear passive system		
Functional failure probability estimation (“True” value, $P(F) = 3.541 \cdot 10^{-4}$)		
	$\hat{P}(F)$	$\hat{\sigma}[\hat{P}(F)]$
Standard MCS	0	$4.483 \cdot 10^{-4}$
SS	$3.720 \cdot 10^{-4}$	$1.679 \cdot 10^{-4}$
LS	$3.527 \cdot 10^{-4}$	$2.143 \cdot 10^{-6}$

Table 6. Values of the functional failure probability estimates $\hat{P}(F)$ and corresponding standard deviations $\hat{\sigma}[\hat{P}(F)]$ obtained by standard MCS, SS and LS with $N_T = 1850$ samples for the nuclear passive system of Section 5.1. The “true” (i.e., reference) value (i.e., $P(F) = 3.541 \cdot 10^{-4}$) obtained by standard MCS with $N_T = 500000$ samples is also reported

Case study 2: nuclear passive system Local reliability sensitivity analysis								
	MCS, $N_T = 500000$ (rank)		MCS, $N_T = 1850$ (rank)		SS, $N_T = 1850$ (rank)		LS, $N_T = 1850$ (rank)	
Parameters	$\partial\hat{P}(F)/\partial\mu_{\theta_j}$	$\partial\hat{P}(F)/\partial\sigma_{\theta_j}$	$\partial\hat{P}(F)/\partial\mu_{\theta_j}$	$\partial\hat{P}(F)/\partial\sigma_{\theta_j}$	$\partial\hat{P}(F)/\partial\mu_{\theta_j}$	$\partial\hat{P}(F)/\partial\sigma_{\theta_j}$	$\partial\hat{P}(F)/\partial\mu_{\theta_j}$	$\partial\hat{P}(F)/\partial\sigma_{\theta_j}$
θ_1	0.1576 (5)	0.0257 (5)	0	0	0.7400 (5)	0.0213 (5)	0.1571 (5)	0.0229 (5)
θ_2	-3.3242 (1)	10.285 (1)	0	0	-3.1262 (1)	8.9068 (1)	-3.3176 (1)	10.233 (1)
θ_3	0.7663 (3)	0.7218 (3)	0	0	0.8580 (3)	0.8090 (3)	0.7638 (3)	0.5424 (3)
θ_4	$3.09 \cdot 10^{-3}$ (9)	$1.48 \cdot 10^{-3}$ (9)	0	0	-0.6697 (6)	0.0150 (6)	$-9.19 \cdot 10^{-3}$ (8)	$7.85 \cdot 10^{-5}$ (8)
θ_5	-0.6275 (4)	0.5228 (4)	0	0	-0.8259 (4)	0.3980 (4)	-0.6344 (4)	0.3741 (4)
θ_6	0.0964 (6)	0.0105 (6)	0	0	0.0933 (9)	$1.05 \cdot 10^{-3}$ (9)	0.0966 (6)	$8.669 \cdot 10^{-3}$ (6)
θ_7	-0.0123 (8)	$1.78 \cdot 10^{-3}$ (8)	0	0	-0.6259 (7)	0.0103 (7)	$-5.77 \cdot 10^{-3}$ (9)	$3.09 \cdot 10^{-5}$ (9)
θ_8	1.0706 (2)	1.0427 (2)	0	0	1.4436 (2)	2.0049 (2)	1.0781 (2)	1.0806 (2)
θ_9	-0.0423 (7)	$5.95 \cdot 10^{-3}$ (7)	0	0	-0.4669 (8)	$1.78 \cdot 10^{-3}$ (8)	-0.0327 (7)	$9.97 \cdot 10^{-3}$ (7)

Table 7. Values of the estimates $\partial\hat{P}(F)/\partial\mu_{\theta_j}$ and $\partial\hat{P}(F)/\partial\sigma_{\theta_j}$ of the partial derivatives

$\partial P(F)/\partial\mu_{\theta_j}$ and $\partial P(F)/\partial\sigma_{\theta_j}$ of the functional failure probability $P(F)$ with respect to the mean μ_{θ_j} and the standard deviation σ_{θ_j} of the distributions of the uncertain input parameters $\{\theta_j; j = 1, 2, \dots, 9\}$, computed in the standard normal space by standard MCS, SS and LS with $N_T = 1850$ samples for the nuclear passive system of Section 5.1; the ranking of the uncertain input parameters is shown in parentheses

Case study 2: nuclear passive system Global sensitivity analysis – Total-order Sobol indices			
Parameters	$S_{Tj}^{y_1}$ (rank)	$S_{Tj}^{y_2}$ (rank)	S_{Tj}^Y (rank)
x_1	$8.846 \cdot 10^{-3}$ (5)	0.0121 (5)	0.0113 (5)
x_2	0.8391 (1)	0.7985 (1)	0.8259 (1)
x_3	0.0434 (4)	0.0682 (3)	0.0546 (4)
x_4	$1.908 \cdot 10^{-4}$ (6)	$3.058 \cdot 10^{-3}$ (8)	$2.226 \cdot 10^{-3}$ (6)
x_5	0.0554 (3)	0.0833 (2)	0.0711 (3)
x_6	$1.559 \cdot 10^{-4}$ (7)	$3.195 \cdot 10^{-3}$ (6)	$2.217 \cdot 10^{-3}$ (7)
x_7	$1.318 \cdot 10^{-4}$ (8)	$3.062 \cdot 10^{-3}$ (7)	$2.201 \cdot 10^{-3}$ (8)
x_8	0.0832 (2)	0.0609 (4)	0.0827 (2)
x_9	$1.134 \cdot 10^{-4}$ (9)	$3.053 \cdot 10^{-3}$ (9)	$2.197 \cdot 10^{-3}$ (9)

Table 8. Values of the total-order Sobol sensitivity indices $S_{Tj}^{y_1}$, $S_{Tj}^{y_2}$ and S_{Tj}^Y , $j = 1, 2, \dots, 9$, obtained with $N_T = 550000$ simulations for the outputs of the T-H code, i.e., $y_1(\mathbf{x}) = T_{out,core}^{hot}(\mathbf{x})$ and $y_2(\mathbf{x}) = T_{out,core}^{avg}(\mathbf{x})$, and for the performance function $Y(\mathbf{x})$ (27) of the passive system of Section 5.1.

The ranking of the uncertain parameters is shown in parentheses

FIGURES

Figure 1




Figure 2




Figure 3




Figure 4




Figure 5

